

NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated July 23, 2002, as supplemented by letters dated November 15, 2002, and January 24, 2003. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209 or 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 12th day of March 2003.

For the Nuclear Regulatory Commission.

**L. Raghavan,**

*Chief, Section 1, Project Directorate III,  
Division of Licensing Project Management,  
Office of Nuclear Reactor Regulation.*

[FR Doc. 03-6544 Filed 3-18-03; 8:45 am]

**BILLING CODE 7590-01-P**

## **NUCLEAR REGULATORY COMMISSION**

### **Advisory Committee on Reactor Safeguards, Subcommittee Meeting on Planning and Procedures; Notice of Meeting**

The ACRS Subcommittee on Planning and Procedures will hold a meeting on April 9, 2003, Room T-2B1, 11545 Rockville Pike, Rockville, Maryland.

The entire meeting will be open to public attendance, with the exception of a portion that may be closed pursuant to 5 U.S.C. 552b(c)(2) and (6) to discuss organizational and personnel matters that relate solely to internal personnel rules and practices of ACRS, and information the release of which would constitute a clearly unwarranted invasion of personal privacy.

The agenda for the subject meeting shall be as follows:

*Wednesday, April 9, 2003—3:30 p.m.*

*until the conclusion of business*

The Subcommittee will discuss proposed ACRS activities and related matters. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions

and actions, as appropriate, for deliberation by the full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official, Mr. Sam Duraiswamy (telephone: 301/415-7364) between 7:30 a.m. and 4:15 p.m. (ET) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Electronic recordings will be permitted only during those portions of the meeting that are open to the public.

Further information regarding this meeting can be obtained by contacting the Designated Federal Official between 7:30 a.m. and 4:15 p.m. (ET). Persons planning to attend this meeting are urged to contact the above named individual at least two working days prior to the meeting to be advised of any potential changes in the agenda.

Dated: March 11, 2003.

**Sher Bahadur,**

*Associate Director for Technical Support,  
ACRS/ACNW.*

[FR Doc. 03-6547 Filed 3-18-03; 8:45 am]

**BILLING CODE 7590-01-P**

## **NUCLEAR REGULATORY COMMISSION**

### **Advisory Committee on Reactor Safeguards, Meeting of the Subcommittee on Plant License Renewal; Notice of Meeting**

The ACRS Subcommittee on Plant License Renewal will hold a meeting on April 9, 2003, Room T-2B3, 11545 Rockville Pike, Rockville, Maryland.

The entire meeting will be open to public attendance.

The agenda for the subject meeting shall be as follows:

*Wednesday, April 9, 2003—8:30 a.m.  
until the conclusion of business.*

The purpose of this meeting is to review the license renewal application for the St. Lucie nuclear plant and the NRC staff's initial Safety Evaluation Report. The Subcommittee will hear presentations by and hold discussions with representatives of the NRC staff, the Florida Power and Light Company, and other interested persons regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official, Mr. Timothy Kobetz (telephone 301/415-8716) five days prior to the meeting, if possible, so that

appropriate arrangements can be made. Electronic recordings will be permitted.

Further information regarding this meeting can be obtained by contacting the Designated Federal Official between 7:30 a.m. and 4:15 p.m. (ET). Persons planning to attend this meeting are urged to contact the above named individual at least two working days prior to the meeting to be advised of any potential changes to the agenda.

Dated: March 11, 2003.

**Sher Bahadur,**

*Associate Director for Technical Support,  
ACRS/ACNW.*

[FR Doc. 03-6548 Filed 3-18-03; 8:45 am]

**BILLING CODE 7590-01-P**

## **NUCLEAR REGULATORY COMMISSION**

### **Draft Regulatory Guide; Issuance, Availability**

The Nuclear Regulatory Commission (NRC) has issued for public comment a proposed revision of a guide in its Regulatory Guide Series. Regulatory Guides are developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques used by the staff in evaluating specific problems or postulated accidents, and data needed by the staff in its review of applications for permits and licenses.

The draft guide is temporarily identified by its task number, DG-1107, which should be mentioned in all correspondence concerning this draft guide. Draft Regulatory Guide DG-1107, "Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident" is being developed to describe methods acceptable to the NRC staff for implementing requirements with respect to the sumps and suppression pools performing the functions of water sources for emergency core cooling, containment heat removal, or containment atmosphere clean up. Section 1.1.4 of DG-1107 contains discussions of active debris mitigation systems in lieu of the passive sump screens that are in many of the nuclear plants. Specifically, comments on alternative solutions to debris strainers for ensuring long-term cooling are solicited.

This draft guide has not received complete staff approval and does not represent an official NRC staff position.

Comments may be accompanied by relevant information or supporting data. Written comments may be submitted by mail to the Rules and Directives Branch,