

§ 292.203

at least some of which is then used for power production.

(Energy Security Act, Pub. L. 96-294, 94 Stat. 611 (1980) Public Utility Regulatory Policies Act of 1978, 16 U.S.C. 2601, *et seq.*, Energy Supply and Environmental Coordination Act, 15 U.S.C. 791 *et seq.*, Federal Power Act, as amended, 16 U.S.C. 792 *et seq.*, Department of Energy Organization Act, 42 U.S.C. 7101 *et seq.*, E.O. 12009, 42 FR 46267)

[45 FR 17972, Mar. 20, 1980, as amended at 45 FR 33958, May 21, 1980; 45 FR 66789, Oct. 8, 1980; Order 135, 46 FR 19231, Mar. 30, 1981; 46 FR 32239, June 22, 1981; Order 499, 53 FR 27002, July 18, 1988; Order 575, 60 FR 4857, Jan. 25, 1995]

§ 292.203 General requirements for qualification.

(a) *Small power production facilities.* Except as provided in paragraph (c) of this section, a small power production facility is a qualifying facility if it:

(1) Meets the maximum size criteria specified in § 292.204(a);

(2) Meets the fuel use criteria specified in § 292.204(b); and

(3) Meets the ownership criteria specified in § 292.206.

(b) *Cogeneration facilities.* A cogeneration facility, including any diesel and dual-fuel cogeneration facility, is a qualifying facility if it:

(1) Meets any applicable operating and efficiency standards specified in § 292.205 (a) and (b); and

(2) Meets the ownership criteria specified in § 292.206.

(c) *Hydroelectric small power production facilities located at a new dam or diversion.* (1) A hydroelectric small power production facility that impounds or diverts the water of a natural watercourse by means of a new dam or diversion (as that term is defined in § 292.202(p)) is a qualifying facility if it meets the requirements of:

(i) Paragraph (a) of this section; and

(ii) Section 292.208.

(2) [Reserved]

[45 FR 17972, Mar. 20, 1980, as amended by Order 70-E, 46 FR 33027, June 26, 1981; 52 FR 5280, Feb. 20, 1987; 52 FR 9161, Mar. 23, 1987; Order 478, 52 FR 28467, July 30, 1987; Order 499, 53 FR 27002, July 18, 1988; Order 541, 57 FR 21734, May 22, 1992]

18 CFR Ch. I (4-1-01 Edition)

§ 292.204 Criteria for qualifying small power production facilities.

(a) *Size of the facility*—(1) *Maximum size.* There is no size limitation for an eligible solar, wind, waste or facility, as defined by section 3(17)(E) of the Federal Power Act. For a non-eligible facility, the power production capacity for which qualification is sought, together with the power production capacity of any other non-eligible small power production facilities that use the same energy resource, are owned by the same person(s) or its affiliates, and are located at the same site, may not exceed 80 megawatts.

(2) *Method of calculation.* (i) For purposes of this paragraph, facilities are considered to be located at the same site as the facility for which qualification is sought if they are located within one mile of the facility for which qualification is sought and, for hydroelectric facilities, if they use water from the same impoundment for power generation.

(ii) For purposes of making the determination in clause (i), the distance between facilities shall be measured from the electrical generating equipment of a facility.

(3) *Waiver.* The Commission may modify the application of paragraph (a)(2) of this section, for good cause.

(b) *Fuel use.* (1)(i) The primary energy source of the facility must be biomass, waste, renewable resources, geothermal resources, or any combination thereof, and 75 percent or more of the total energy input must be from these sources.

(ii) Any primary energy source which, on the basis of its energy content, is 50 percent or more biomass shall be considered biomass.

(2) Use of oil, natural gas and coal by a facility, under section 3(17)(B) of the Federal Power Act, is limited to the minimum amounts of fuel required for ignition, startup, testing, flame stabilization, and control uses, and the minimum amounts of fuel required to alleviate or prevent unanticipated equipment outages, and emergencies, directly affecting the public health, safety, or welfare, which would result from electric power outages. Such fuel use may not, in the aggregate, exceed 25 percent of the total energy input of the facility during the 12-month period