

§ 435.104

10 CFR Ch. II (1–1–01 Edition)

Table 3.5-2  
Power Adjustment Factor (PAF)

AUTOMATIC CONTROL DEVICE(S)	STANDARD PAF*
(1) Occupancy sensor	0.30
(2) Daylight Sensing continuous dimming	0.30
(3) Daylight Sensing multiple step dimming	0.20
(4) Daylight Sensing ON/OFF	0.10
(5) Lumen maintenance	0.10

\* - Power Adjustment Factor cannot be used for incandescent fixtures.

- (a) Programmable for different schedules for occupied and unoccupied days;
- (b) Accessible for temporary override by occupants of individual zones, spaces or tasks, with automatic return to the original schedules; and
- (c) Capable of keeping time during power outages for a minimum of four hours.

§ 435.104 Auxiliary systems and equipment.

4.1 General

This section contains a few minimum requirements for auxiliary systems and equipment. Because auxiliary systems and equipment vary greatly among buildings, the section is not more comprehensive.

4.2 Principles of Design

4.2.1 Energy recovery should be used when coincident thermal and refrigeration loads of similar magnitude are expected.

4.2.2 Consideration shall be given to the use of waste heat, energy recovery or heat tape systems to conserve energy.

4.3 Minimum Requirements

4.3.1 Transportation Systems.

4.3.1.1 Automatic elevator and/or conveyor systems shall incorporate schedule controls and efficient motor controls, such as solid state control devices.

4.3.2 Freeze Protection System.

4.3.2.1 Boilers or water heaters used for purposes such as freeze protection in fire protection storage vessels and defrosting sidewalks and driveways

shall meet the efficiency requirements of sections 8.3 or 9.3 when they operate in excess of 750 hours per year.

4.3.3 Retail Food and Food Service Refrigeration.

4.3.3.1 Refrigeration systems containing multiple compressors shall have compressors sized to optimally match capacity with loads.

4.3.3.2 Variable speed shall be considered.

§ 435.105 Building Envelope.

5.1 General

5.1.1 This section contains requirements for the energy conscious design of building envelopes. It sets principles of good envelope design, and provides a set of minimum requirements and two alternative compliance paths—prescriptive and system performance.

5.1.2 *Compliance.* A building shall be considered in Compliance with this section if the following conditions are met:

5.1.2.1 The minimum requirements of Section 5.3 are met;

5.1.2.2 The design of the building envelope complies with either the prescriptive criteria of section 5.4 or the system performance criteria of section 5.5. For the design of buildings with high internal heat gains, unusual operating schedules, or that incorporate innovative design strategies, consideration shall be given to using the compliance paths set forth in sections 11.0 or 12.0.

5.1.3 The prescriptive compliance alternative of section 5.4 provides requirements for buildings designed to take advantage of perimeter daylighting, thermal mass, high performance glazings, and fenestration shading. The designer is allowed to make trade-offs between thermal mass, wall insulation, amount of fenestration, shading coefficients, shading projections, thermal transmittance of the glazing, daylighting for several different climate locations.

5.1.4 The systems performance compliance alternative of section 3.5 provides calculation procedures that give credit for the benefits of more complex energy conserving envelope designs.