

Environmental Protection Agency

§ 437.43

(d) Combined waste receipts from subparts A and C of this part. (1) As provided in §437.42(a), any existing point source subject to this paragraph must achieve the following effluent limitations representing the application of BPT:

BPT LIMITATIONS		
Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
Conventional Parameters		
BOD ₅	163	3.0
O&G	205	50.2
pH	(²)	(²)
TSS	60.0	31.0
Metal Parameters		
Antimony	0.249	0.206
Arsenic	0.162	0.104
Cadmium	0.474	0.0962
Chromium	15.5	3.07
Cobalt	0.192	0.124
Copper	0.865	0.757
Lead	1.32	0.283
Mercury	0.00234	0.000739
Molybdenum	1.01	0.965
Nickel	3.95	1.45
Selenium	1.64	0.408
Silver	0.120	0.0351
Tin	0.409	0.120
Titanium	0.0947	0.0618
Vanadium	0.218	0.0662
Zinc	0.497	0.420
Organic Parameters		
Acetone	30.2	7.97
Acetophenone	0.114	0.0562
Aniline	0.0333	0.0164
2-Butanone	4.81	1.85
o-Cresol	1.92	0.561
p-Cresol	0.698	0.205
2,3-Dichloroaniline	0.0731	0.0361
Phenol	3.65	1.08
Pyridine	0.370	0.182
2,4,6-Trichlorophenol	0.155	0.106

¹ mg/L (ppm).
² Within the range 6 to 9.

(2) The following in-plant limitations apply to metal-bearing wastewater containing cyanide:

IN-PLANT LIMITATIONS		
Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
Cyanide	500	178

¹ mg/L (ppm).

(e) Combined waste receipts from subparts B and C of this part. As provided in §437.42(a), any existing point source subject to this paragraph must achieve the following effluent limita-

tions representing the application of BPT:

BPT LIMITATIONS		
Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
Conventional Parameters		
BOD ₅	163	53.0
O&G	127	38.0
pH	(²)	(²)
TSS	74.1	30.6
Metal Parameters		
Antimony	0.237	0.141
Arsenic	2.95	1.33
Barium	0.427	0.281
Cadmium	0.0172	0.0102
Chromium	0.746	0.323
Cobalt	56.4	18.8
Copper	0.500	0.242
Lead	0.350	0.160
Mercury	0.0172	0.00647
Molybdenum	1.01	0.965
Tin	0.335	0.165
Titanium	0.0510	0.0299
Zinc	0.497	0.420
Organic Parameters		
Acetone	30.2	7.97
Acetophenone	0.114	0.0562
Aniline	0.0333	0.0164
Bis(2-ethylhexyl) phthalate	0.215	0.101
2-Butanone	4.81	1.85
Butylbenzyl phthalate	0.188	0.0887
Carbazole	0.598	0.276
o-Cresol	1.92	0.561
p-Cresol	0.698	0.205
n-Decane	0.948	0.437
2,3-Dichloroaniline	0.0731	0.0361
Fluoranthene	0.0537	0.0268
n-Octadecane	0.589	0.302
Phenol	3.65	1.08
Pyridine	0.370	0.182
2,4,6-Trichlorophenol	0.155	0.106

¹ mg/L (ppm).
² Within the range 6 to 9.

§ 437.43 Effluent limitations attainable by the application of the best conventional pollutant control technology (BCT).

(a) Except as provided in 40 CFR 125.30 through 125.32 or 437.40(b), any existing facility subject to this subpart which combines treated or untreated wastes from subparts A, B, or C of this part may be subject to Multiple Wastestream Subcategory effluent limitations representing the application of BCT set forth in paragraphs (b), (c), (d), or (e) of this section if the discharger agrees to the following conditions in its NPDES permit:

§ 437.44

40 CFR Ch. I (7-1-02 Edition)

(1) The discharger will meet the applicable Multiple Wastestream Subcategory limitations set forth in paragraphs (b), (c), (d) or (e) of this section;

(2) The discharger will notify its NPDES permit writer at the time of renewal or modification of its permit, of its desire to be subject to the Multiple Waste Subcategory by submitting to the NPDES permit writer an initial certification statement as described in § 437.41(a);

(3) The discharger will submit to its NPDES permitting authority a periodic certification statement as described in § 437.41(b) once a year; and

(4) The discharger will maintain at the office of the facility and make available for inspection the on-site compliance paperwork as described in § 437.41(c).

(b) Combined waste receipts from subparts A, B and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(b).

(c) Combined waste receipts from subparts A and B of this part: Limitations for O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(c).

(d) Combined waste receipts from subparts A and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(d).

(e) Combined waste receipts from subparts B and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(e).

§ 437.44 Effluent limitations attainable by the application of the best available technology economically achievable (BAT).

(a) Except as provided in 40 CFR 125.30 through 125.32 or 437.40(b), any existing facility subject to this subpart which combines treated or untreated wastes from subparts A, B, or C of this part may be subject to Multiple Wastestream Subcategory effluent limitations representing the application of BAT set forth in paragraphs (b), (c), (d), or (e) of this section if the discharger agrees to the following conditions in its NPDES permit:

(1) The discharger will meet the applicable Multiple Wastestream Subcategory limitations set forth in paragraphs (b), (c), (d) or (e) of this section;

(2) The discharger will notify its NPDES permit writer at the time of renewal or modification of its permit, of its desire to be subject to the Multiple Waste Subcategory by submitting to the NPDES permit writer an initial certification statement as described in § 437.41(a);

(3) The discharger will submit to its NPDES permitting authority a periodic certification statement as described in § 437.41(b) once a year; and

(4) The discharger will maintain at the office of the facility and make available for inspection the on-site compliance paperwork as described in § 437.41(c).

(b) Combined waste receipts from subparts A, B and C of this part. (1) Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(b)(1):

Organic parameters	Metal parameters
Acetone	Antimony.
Acetophenone	Arsenic.
Aniline	Barium.
bis (2-ethylhexyl) phthalate ...	Cadmium.
2-Butanone	Chromium.
Butylbenzyl phthalate	Cobalt.
Carbazole	Copper.
o-Cresol	Lead.
p-Cresol	Mercury.
n-Decane	Molybdenum.
2,3-dichloroaniline	Nickel.
Fluoranthene	Selenium.
n-Octadecane	Silver.
Phenol	Tin.
Pyridine	Titanium.
2,4,6-trichlorophenol	Vanadium.
	Zinc.

(2) The in-plant limitations that apply to metal-bearing wastewater containing cyanide are the same as the corresponding limitations specified in § 437.42(b)(2).

(c) Combined waste receipts from subparts A and B of this part. (1) Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(c)(1):

Organic parameters	Metal parameters
Bis (2-ethylhexyl) phthalate ...	Antimony.
Butylbenzyl phthalate	Arsenic.
Carbazole	Barium.
n-Decane	Cadmium.
Fluoranthene	Chromium.