

§ 437.44

40 CFR Ch. I (7-1-02 Edition)

(1) The discharger will meet the applicable Multiple Wastestream Subcategory limitations set forth in paragraphs (b), (c), (d) or (e) of this section;

(2) The discharger will notify its NPDES permit writer at the time of renewal or modification of its permit, of its desire to be subject to the Multiple Waste Subcategory by submitting to the NPDES permit writer an initial certification statement as described in § 437.41(a);

(3) The discharger will submit to its NPDES permitting authority a periodic certification statement as described in § 437.41(b) once a year; and

(4) The discharger will maintain at the office of the facility and make available for inspection the on-site compliance paperwork as described in § 437.41(c).

(b) Combined waste receipts from subparts A, B and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(b).

(c) Combined waste receipts from subparts A and B of this part: Limitations for O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(c).

(d) Combined waste receipts from subparts A and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(d).

(e) Combined waste receipts from subparts B and C of this part: Limitations for BOD₅, O&G, pH, and TSS are the same as the corresponding limitation specified in § 437.42(e).

§ 437.44 Effluent limitations attainable by the application of the best available technology economically achievable (BAT).

(a) Except as provided in 40 CFR 125.30 through 125.32 or 437.40(b), any existing facility subject to this subpart which combines treated or untreated wastes from subparts A, B, or C of this part may be subject to Multiple Wastestream Subcategory effluent limitations representing the application of BAT set forth in paragraphs (b), (c), (d), or (e) of this section if the discharger agrees to the following conditions in its NPDES permit:

(1) The discharger will meet the applicable Multiple Wastestream Subcategory limitations set forth in paragraphs (b), (c), (d) or (e) of this section;

(2) The discharger will notify its NPDES permit writer at the time of renewal or modification of its permit, of its desire to be subject to the Multiple Waste Subcategory by submitting to the NPDES permit writer an initial certification statement as described in § 437.41(a);

(3) The discharger will submit to its NPDES permitting authority a periodic certification statement as described in § 437.41(b) once a year; and

(4) The discharger will maintain at the office of the facility and make available for inspection the on-site compliance paperwork as described in § 437.41(c).

(b) Combined waste receipts from subparts A, B and C of this part. (1) Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(b)(1):

Organic parameters	Metal parameters
Acetone	Antimony.
Acetophenone	Arsenic.
Aniline	Barium.
bis (2-ethylhexyl) phthalate ...	Cadmium.
2-Butanone	Chromium.
Butylbenzyl phthalate	Cobalt.
Carbazole	Copper.
o-Cresol	Lead.
p-Cresol	Mercury.
n-Decane	Molybdenum.
2,3-dichloroaniline	Nickel.
Fluoranthene	Selenium.
n-Octadecane	Silver.
Phenol	Tin.
Pyridine	Titanium.
2,4,6-trichlorophenol	Vanadium.
	Zinc.

(2) The in-plant limitations that apply to metal-bearing wastewater containing cyanide are the same as the corresponding limitations specified in § 437.42(b)(2).

(c) Combined waste receipts from subparts A and B of this part. (1) Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(c)(1):

Organic parameters	Metal parameters
Bis (2-ethylhexyl) phthalate ...	Antimony.
Butylbenzyl phthalate	Arsenic.
Carbazole	Barium.
n-Decane	Cadmium.
Fluoranthene	Chromium.

Environmental Protection Agency

§ 437.45

Organic parameters	Metal parameters
n-Octadecane	Cobalt. Copper. Lead. Mercury. Molybdenum. Nickel. Selenium. Silver. Tin. Titanium. Vanadium. Zinc.

(2) The in-plant limitations that apply to metal-bearing wastewater containing cyanide are the same as the corresponding limitations specified in § 437.42(c)(2).

(d) Combined waste receipts from subparts A and C of this part. (1) Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(d)(1):

Organic parameters	Metal parameters
Acetone	Antimony.
Acetophenone	Arsenic.
Aniline	Cadmium.
2-Butanone	Chromium.
o-Cresol	Cobalt.
p-Cresol	Copper.
Phenol	Lead.
Pyridine	Mercury.
2,4,6-trichlorophenol	Molybdenum. Nickel. Selenium. Silver. Tin. Titanium. Vanadium. Zinc.

(2) The in-plant limitations that apply to metal-bearing wastewater containing cyanide are the same as the corresponding limitations specified in § 437.42(e)(2).

(e) Combined waste receipts from subparts B and C of this part. Limitations for the following parameters are the same as the corresponding limitation specified in § 437.42(e):

Organic parameters	Metal parameters
Acetone	Antimony.
Acetophenone	Arsenic.
Aniline	Barium.
Bis(2-ethylhexyl) phthalate	Cadmium.
2-Butanone	Chromium.
Butylbenzyl phthalate	Cobalt.
Carbazole	Copper.
o-Cresol	Lead.
p-Cresol	Mercury.
n-Decane	Molybdenum.
2,3-dichloroaniline	Tin.
Fluoranthene	Titanium.

Organic parameters	Metal parameters
n-Octadecane Phenol Pyridine 2,4,6-trichlorophenol	Zinc.

§ 437.45 New source performance standards (NSPS).

(a) Except as provided in § 437.40(b), any new source subject to this subpart which combines treated or untreated wastes from subparts A, B, or C of this part may be subject to Multiple Wastestream Subcategory effluent limitations representing the application of NSPS set forth in paragraphs (b), (c), (d), or (e) of this section if the discharger agrees to the following conditions in its NPDES permit:

(1) The discharger will meet the applicable Multiple Wastestream Subcategory limitations set forth in paragraphs (b), (c), (d) or (e) of this section;

(2) The discharger will notify its NPDES permit writer at the time of submitting its application for permit, of its desire to be subject to the Multiple Waste Subcategory by submitting to the NPDES permit writer an initial certification statement as described in § 437.41(a);

(3) The discharger will submit to its NPDES permitting authority a periodic certification statement as described in § 437.41(b) once a year; and

(4) The discharger will maintain at the office of the facility and make available for inspection the on-site compliance paperwork as described in § 437.41(c).

(b) Combined waste receipts from subparts A, B and C of this part. (1) As provided in § 437.45(a), any new source subject to this paragraph must achieve the following performance standards:

PERFORMANCE STANDARDS

Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
Conventional Parameters		
BOD ₅	163	53.0
O&G	127	38.0
pH	(²)	(²)
TSS	29.6	11.3
Metal Parameters		
Antimony	0.111	0.0312
Arsenic	0.0993	0.0199
Barium	0.427	0.281