

sampling scheme and the guidance document are available from the Director, Environmental Assistance Division (7408), Office of Pollution Prevention and Toxics, U.S. Environmental Protection Agency, Room E-543B, 1200 Pennsylvania Ave., NW., Washington, DC 20460, Telephone: (202) 554-1404, TDD: (202) 544-0551. The major advantage of this sampling scheme is that it is designed to characterize the degree of contamination within the entire sampling area with a high degree of confidence while using fewer samples than any other grid or random sampling scheme. This sampling scheme also allows some sites to be characterized on the basis of composite samples.

(f) EPA may, at its discretion, take samples from any spill site. If EPA's sampling indicates that the remaining concentration level exceeds the required level, EPA will require further cleanup. For this purpose, the numerical level of cleanup required for spills cleaned in accordance with § 761.125(b) is deemed to be the equivalent of numerical cleanup requirements required for cleanups under § 761.125(c) (2) through (4). Using its best engineering judgment, EPA may sample a statistically valid random or grid sampling technique, or both. When using engineering judgment or random "grab" samples, EPA will take into account that there are limits on the power of a grab sample to dispute statistically based sampling of the type required of the responsible party. EPA headquarters will provide guidance to the EPA regions on the degree of certainty associated with various grab sample results.

[52 FR 10705, Apr. 2, 1987, as amended at 60 FR 34465, July 3, 1995]

§ 761.135 Effect of compliance with this policy and enforcement.

(a) Although a spill of material containing 50 ppm or greater PCBs is considered improper PCB disposal, this policy establishes requirements that EPA considers to be adequate cleanup of the spilled PCBs. Cleanup in accordance with this policy means compliance with the procedural as well as the numerical requirements of this policy. Compliance with this policy creates a presumption against both enforcement

action for penalties and the need for further cleanup under TSCA. The Agency reserves the right, however, to initiate appropriate action to compel cleanup where, upon review of the records of cleanup or EPA sampling following cleanup, EPA finds that the decontamination levels in the policy have not been achieved. The Agency also reserves the right to seek penalties where the Agency believes that the responsible party has not made a good faith effort to comply with all provisions of this policy, such as prompt notification of EPA of a spill, recordkeeping, etc.

(b) EPA's exercise of enforcement discretion does not preclude enforcement action under other provisions of TSCA or any other Federal statute. This includes, even in cases where the numerical decontamination levels set forth in this policy have been met, civil or criminal action for penalties where EPA believes the spill to have been the result of gross negligence or knowing violation.

Subparts H-I [Reserved]

Subpart J—General Records and Reports

§ 761.180 Records and monitoring.

This section contains recordkeeping and reporting requirements that apply to PCBs, PCB Items, and PCB storage and disposal facilities that are subject to the requirements of the part.

(a) *PCBs and PCB Items in service or projected for disposal.* Beginning February 5, 1990, each owner or operator of a facility, other than a commercial storer or a disposer of PCB waste, using or storing at any one time at least 45 kilograms (99.4 pounds) of PCBs contained in PCB Container(s), or one or more PCB Transformers, or 50 or more PCB Large High or Low Voltage Capacitors shall develop and maintain at the facility, or a central facility provided they are maintained at that facility, all annual records and the written annual document log of the disposition of PCBs and PCB Items. The written annual document log must be prepared for each facility by July 1 covering the previous calendar year (January through December). The annual