

### § 35.1335

(i) Impermanent surface coverings may be used to treat lead-contaminated soil if applied in accordance with the following requirements. Examples of acceptable impermanent coverings include gravel, bark, sod, and artificial turf.

(A) Impermanent surface coverings selected shall be designed to withstand the reasonably-expected traffic. For example, if the area to be treated is heavily traveled, neither grass or sod shall be used.

(B) When loose impermanent surface coverings such as bark or gravel are used, they shall be applied in a thickness not less than six inches deep.

(C) The impermanent surface covering material shall not contain more than 200 µg/g of lead.

(D) Adequate controls to prevent erosion shall be used in conjunction with impermanent surface coverings.

(ii) Land use controls may be used to reduce exposure to soil-lead hazards only if they effectively control access to areas with soil-lead hazards. Examples of land use controls include: fencing, warning signs, and landscaping.

(A) Land use controls shall be implemented only if residents have reasonable alternatives to using the area to be controlled.

(B) If land use controls are used for a soil area that is subject to erosion, measures shall be taken to contain the soil and control dispersion of lead.

### § 35.1335 Standard treatments.

Standard treatments shall be conducted in accordance with this section.

(a) *Paint stabilization.* All deteriorated paint on exterior and interior surfaces located on the residential property shall be stabilized in accordance with § 35.1330(a)(b), or abated in accordance with § 35.1325.

(b) *Smooth and cleanable horizontal surfaces.* All horizontal surfaces, such as uncarpeted floors, stairs, interior window sills and window troughs, that are rough, pitted, or porous, shall be covered with a smooth, cleanable covering or coating, such as metal coil stock, plastic, polyurethane, or linoleum.

(c) *Correcting dust-generating conditions.* Conditions causing friction or impact of painted surfaces shall be cor-

### 24 CFR Subtitle A (4-1-03 Edition)

rected in accordance with § 35.1330(c)(4)-(6).

(d) *Bare residential soil.* Bare soil shall be treated in accordance with the requirements of § 35.1330, unless it is found not to be a soil-lead hazard in accordance with § 35.1320(b).

(e) *Safe work practices.* All standard treatments described in paragraphs (a) through (d) of this section shall incorporate the use of safe work practices in accordance with § 35.1350.

(f) *Clearance.* A clearance examination shall be performed in accordance with § 35.1340 at the conclusion of any lead hazard reduction activities.

(g) *Qualifications.* An individual performing standard treatments must meet the training and/or supervision requirements of § 35.1330(a)(4).

### § 35.1340 Clearance.

Clearance examinations required under subparts B, C, D, F through M, and R, of this part shall be performed in accordance with the provisions of this section.

(a) *Clearance following abatement.* Clearance examinations performed following abatement of lead-based paint or lead-based paint hazards shall be performed in accordance with 40 CFR 745.227(e) and paragraphs (c)-(f) of this section. Such clearances shall be performed by a person certified to perform risk assessments or lead-based paint inspections.

(b) *Clearance following activities other than abatement.* Clearance examinations performed following interim controls, paint stabilization, standard treatments, ongoing lead-based paint maintenance, or rehabilitation shall be performed in accordance with the requirements of this paragraph (b) and paragraphs (c)-(g) of this section.

(1) *Qualified personnel.* Clearance examinations shall be performed by:

(i) A certified risk assessor;

(ii) A certified lead-based paint inspector;

(iii) A person who has successfully completed a training course for clearance technicians (or a discipline of similar purpose and title) that is developed or accepted by EPA or a State or tribal program authorized by EPA pursuant to 40 CFR part 745, subpart Q, and that is given by a training provider

accredited by EPA or a State or Indian tribe for training in lead-based paint inspection or risk assessment, *provided* a certified risk assessor or a certified lead-based paint inspector approves the work of the clearance technician and signs the report of the clearance examination; or

(iv) A technician licensed or certified by EPA or a State or Indian tribe to perform clearance examinations without the approval of a certified risk assessor or certified lead-based paint inspector, *provided* that a clearance examination by such a licensed or certified technician shall be performed only for a single-family property or individual dwelling units and associated common areas in a multi-unit property, and provided further that a clearance examination by a such a licensed or certified clearance technician shall not be performed using random sampling of dwelling units or common areas in multifamily properties, except that a clearance examination performed by such a licensed or certified clearance technician is acceptable for any residential property if the clearance examination is approved and the report signed by a certified risk assessor or a certified lead-based paint inspector.

(2) *Required activities.* (i) Clearance examinations shall include a visual assessment, dust sampling, submission of samples for analysis for lead, interpretation of sampling results, and preparation of a report. Clearance examinations shall be performed in dwelling units, common areas and exterior areas in accordance with this section and the steps set forth at 40 CFR 745.227(e)(8). If clearance is being performed for more than 10 dwelling units of similar construction and maintenance, as in a multifamily property, random sampling for the purposes of clearance may be conducted in accordance with 40 CFR 745.227(e)(9).

(ii) The visual assessment shall be performed to determine if deteriorated paint surfaces and/or visible amounts of dust, debris, paint chips or other residue are still present. Both exterior and interior painted surfaces shall be examined for the presence of deteriorated paint. If deteriorated paint or visible dust, debris or residue are

present in areas subject to dust sampling, they must be eliminated prior to the continuation of the clearance examination, except elimination of deteriorated paint is not required if it has been determined, through paint testing or a lead-based paint inspection, that the deteriorated paint is not lead-based paint. If exterior painted surfaces have been disturbed by the hazard reduction, maintenance or rehabilitation activity, the visual assessment shall include an assessment of the ground and any outdoor living areas close to the affected exterior painted surfaces. Visible dust or debris in living areas shall be cleaned up and visible paint chips on the ground shall be removed.

(iii) Dust samples shall be wipe samples and shall be taken on floors and, where practicable, interior window sills and window troughs. Dust samples shall be collected and analyzed in accordance with § 35.1315 of this part.

(iv) Clearance reports shall be prepared in accordance with paragraph (c) of this section.

(c) *Clearance report.* When clearance is required, the designated party shall ensure that a clearance report is prepared that provides documentation of the hazard reduction or maintenance activity as well as the clearance examination. When abatement is performed, the report shall be an abatement report in accordance with 40 CFR 745.227(e)(10). When another hazard reduction or maintenance activity requiring a clearance report is performed, the report shall include the following information:

(1) The address of the residential property and, if only part of a multifamily property is affected, the specific dwelling units and common areas affected.

(2) The following information on the clearance examination:

(i) The date(s) of the clearance examination;

(ii) The name, address, and signature of each person performing the clearance examination, including certification number;

(iii) The results of the visual assessment for the presence of deteriorated paint and visible dust, debris, residue or paint chips;

### § 35.1345

(iv) The results of the analysis of dust samples, in  $\mu\text{g}/\text{sq. ft.}$ , by location of sample; and

(v) The name and address of each laboratory that conducted the analysis of the dust samples, including the identification number for each such laboratory recognized by EPA under section 405(b) of the Toxic Substances Control Act (15 U.S.C. 2685(b)).

(3) The following information on the hazard reduction or maintenance activity for which clearance was performed:

(i) The start and completion dates of the hazard reduction or maintenance activity;

(ii) The name and address of each firm or organization conducting the hazard reduction or maintenance activity and the name of each supervisor assigned;

(iii) A detailed written description of the hazard reduction or maintenance activity, including the methods used, locations of exterior surfaces, interior rooms, common areas, and/or components where the hazard reduction activity occurred, and any suggested monitoring of encapsulants or enclosures; and

(iv) If soil hazards were reduced, a detailed description of the location(s) of the hazard reduction activity and the method(s) used.

(d) *Standards.* The clearance standards in § 35.1320(b)(2) shall apply. If test results equal or exceed the standards, the dwelling unit, worksite, or common area represented by the sample fails the clearance examination.

(e) *Clearance failure.* All surfaces represented by a failed clearance sample shall be recleaned or treated by hazard reduction, and retested, until the applicable clearance level in § 35.1320(b)(2) is met.

(f) *Independence.* Clearance examinations shall be performed by persons or entities independent of those performing hazard reduction or maintenance activities, unless the designated party uses qualified in-house employees to conduct clearance. An in-house employee shall not conduct both a hazard reduction or maintenance activity and its clearance examination.

(g) *Worksite clearance.* When clearance is of an interior worksite, not an entire dwelling unit or residential property,

### 24 CFR Subtitle A (4-1-03 Edition)

dust samples taken for paragraph (b) of this section shall be taken from the floor and window (if available) to represent the area within the dust containment area. Clearance is not required if maintenance or hazard reduction activities in the worksite do not disturb painted surfaces of a total area more than that set forth in § 35.1350(d)

### § 35.1345 Occupant protection and worksite preparation.

This section establishes procedures for protecting dwelling unit occupants and the environment from contamination from lead-contaminated or lead-containing materials during hazard reduction activities.

(a) *Occupant protection.* (1) Occupants shall not be permitted to enter the worksite during hazard reduction activities (unless they are employed in the conduct of these activities at the worksite), until after hazard reduction work has been completed and clearance, if required, has been achieved.

(2) Occupants shall be temporarily relocated before and during hazard reduction activities to a suitable, decent, safe, and similarly accessible dwelling unit that does not have lead-based paint hazards, except if:

(i) Treatment will not disturb lead-based paint, dust-lead hazards or soil-lead hazards;

(ii) Only the exterior of the dwelling unit is treated, and windows, doors, ventilation intakes and other openings in or near the worksite are sealed during hazard control work and cleaned afterward, and entry free of dust-lead hazards, soil-lead hazards, and debris is provided;

(iii) Treatment of the interior will be completed within one period of 8-day-time hours, the worksite is contained so as to prevent the release of leaded dust and debris into other areas, and treatment does not create other safety, health or environmental hazards (e.g., exposed live electrical wiring, release of toxic fumes, or on-site disposal of hazardous waste); or

(iv) Treatment of the interior will be completed within 5 calendar days, the worksite is contained so as to prevent the release of leaded dust and debris into other areas, treatment does not