

§ 51.202

Thermal radiation level—means the emission and propagation of heat energy through space or a material medium, expressed in BTU per square foot per hour (BTU/ft.² hr.).

[49 FR 5103, Feb. 10, 1984, as amended at 61 FR 5204, Feb. 9, 1996; 61 FR 13334, Mar. 26, 1996]

§ 51.202 Approval of HUD-assisted projects.

(a) The Department will not approve an application for assistance for a proposed project located at less than the acceptable separation distance from a hazard, as defined in § 51.201, unless appropriate mitigating measures, as defined in § 51.205, are implemented, or unless mitigating measures are already in place.

(b) In the case of all applications for proposed HUD-assisted projects, the Department shall evaluate projected development plans in the vicinity of these projects to determine whether there are plans to install a hazardous operation in close proximity to the proposed project. If the evaluation shows that such a plan exists, the Department shall not approve assistance for the project unless the Department obtains satisfactory assurances that adequate mitigating measures will be taken when the hazardous operation is installed.

[49 FR 5103, Feb. 10, 1984, as amended at 61 FR 13334, Mar. 26, 1996]

§ 51.203 Safety standards.

The following standards shall be used in determining the acceptable separation distance of a proposed HUD-assisted project from a hazard:

(a) *Thermal Radiation Safety Standard.* Projects shall be located so that:

(1) The allowable thermal radiation flux level at the building shall not exceed 10,000 BTU/sq. ft. per hr.;

(2) The allowable thermal radiation flux level for outdoor, unprotected facilities or areas of congregation shall not exceed 450 BTU/sq. ft. per hour.

(b) *Blast Overpressure Safety Standard.* Projects shall be located so that the maximum allowable blast overpressure at both buildings and outdoor, unprotected facilities or areas shall not exceed 0.5 psi.

24 CFR Subtitle A (4-1-03 Edition)

(c) If a hazardous substance constitutes both a thermal radiation and blast overpressure hazard, the ASD for each hazard shall be calculated, and the larger of the two ASDs shall be used to determine compliance with this subpart.

(d) Background information on the standards and the logarithmic thermal radiation and blast overpressure charts that provide assistance in determining acceptable separation distances are contained in appendix II to this subpart C.

[49 FR 5103, Feb. 10, 1984, as amended at 61 FR 13334, Mar. 26, 1996]

§ 51.204 HUD-assisted hazardous facilities.

In reviewing applications for proposed HUD-assisted projects involving the installation of hazardous facilities, the Department shall ensure that such hazardous facilities are located at an acceptable separation distance from residences and from any other facility or area where people may congregate or be present. The mitigating measures listed in § 51.205 may be taken into account in determining compliance with this section.

§ 51.205 Mitigating measures.

Application of the standards for determining an Acceptable Separation Distance (ASD) for a HUD-assisted project from a potential hazard of an explosion or fire prone nature is predicated on level topography with no intervening object(s) between the hazard and the project. Application of the standards can be eliminated or modified if:

(a) The nature of the topography shields the proposed project from the hazard.

(b) An existing permanent fire resistant structure of adequate size and strength will shield the proposed project from the hazard.

(c) A barrier is constructed surrounding the hazard, at the site of the project, or in between the potential hazard and the proposed project.

(d) The structure and outdoor areas used by people are designed to withstand blast overpressure and thermal

Office of the Secretary, HUD

Pt. 51, Subpt. C, App. II

radiation anticipated from the potential hazard (e.g., the project is of masonry and steel or reinforced concrete and steel construction).

§ 51.206 Implementation.

This subpart C shall be implemented for each proposed HUD-assisted project by the HUD approving official or responsible entity responsible for review of the project. The implementation procedure will be part of the environmental review process in accordance with the procedures set forth in 24 CFR parts 50 and 58.

[61 FR 13334, Mar. 26, 1996]

§ 51.207 Special circumstances.

The Secretary or the Secretary's designee may, on a case-by-case basis, when circumstances warrant, require the application of this subpart C with respect to a substance not listed in appendix I to this subpart C that would create thermal or overpressure effect in excess of that listed in § 51.203.

[61 FR 13334, Mar. 26, 1996]

§ 51.208 Reservation of administrative and legal rights.

Publication of these standards does not constitute a waiver of any right: (a) Of HUD to disapprove a project proposal if the siting is too close to a potential hazard not covered by this subpart, and (b) of HUD or any person or other entity to seek to abate or to collect damages occasioned by a nuisance, whether or not covered by the subpart.

**APPENDIX I TO SUBPART C OF PART 51—
SPECIFIC HAZARDOUS SUBSTANCES**

The following is a list of specific petroleum products and chemicals defined to be hazardous substances under § 51.201.

HAZARDOUS LIQUIDS

Acetic Acid	Cellosolve
Acetic Anhydride	Cresols
Acetone	Crude Oil
Acrylonitrile	(Petroleum)
Amyl Acetate	Cumene
Amyl Alcohol	Cyclohexane
Benzene	No. 2 Diesel Fuel
Butyl Acetate	Ethyl Acetate
Butyl Acrylate	Ethyl Acrylate
Butyl Alcohol	Ethyl Alcohol
Carbon Bisulfide	Ethyl Benzene
Carbon Disulfide	Ethyl Dichloride

Ethyl Ether	Methyl Alcohol
Gasoline	Methyl Amyl Alcohol
Heptane	Methyl Cellosolve
Hexane	Methyl Ethyl Ketone
Isobutyl Acetate	Naptha
Isobutyl Alcohol	Pentane
Isopropyl Acetate	Propylene Oxide
Isopropyl Alcohol	Toluene
Jet Fuel and	Vinyl Acetate
Kerosene	Xylene

HAZARDOUS GASES

Acetaldehyde	Liquefied Natural
Butadiene	Gas (LNG)
Butane	Liquefied Petroleum
Ethene	Gas (LPG)
Ethylene	Propane
Ethylene Oxide	Propylene
Hydrogen	Vinyl Chloride

(Primary Source: "Urban Development Siting with respect to Hazardous Commercial/Industrial Facilities," by Rolf Jensen and Associates, Inc., April 1982)

[49 FR 5105, Feb. 10, 1984; 49 FR 12214, Mar. 29, 1984]

**APPENDIX II TO SUBPART C OF PART 51—
DEVELOPMENT OF STANDARDS; CAL-
CULATION METHODS**

I. Background Information Concerning the Standards

(a) Thermal Radiation:

(1) *Introduction.* Flammable products stored in above ground containers represent a definite, potential threat to human life and structures in the event of fire. The resulting fireball emits thermal radiation which is absorbed by the surroundings. Combustible structures, such as wooden houses, may be ignited by the thermal radiation being emitted. The radiation can cause severe burn, injuries and even death to exposed persons some distance away from the site of the fire.

(2) *Criteria for Acceptable Separation Distance (ASD).* Wooden buildings, window drapes and trees generally ignite spontaneously when exposed for a relatively long period of time to thermal radiation levels of approximately 10,000 Btu/hr. sq. ft. It will take 15 to 20 minutes for a building to ignite at that degree of thermal intensity. Since the reasonable response time for fire fighting units in urbanized areas is approximately five to ten minutes, a standard of 10,000 BTU/hr. sq. ft. is considered an acceptable level of thermal radiation for buildings.

People in outdoor areas exposed to a thermal radiation flux level of approximately 1,500 Btu/ft² hr will suffer intolerable pain after 15 seconds. Longer exposure causes blistering, permanent skin damage, and even death. Since it is assumed that children and the elderly could not take refuge behind walls or run away from the thermal effect of