

§ 403.16

40 CFR Ch. I (7-1-03 Edition)

limits are placed on process water pollutants either at the outfall or elsewhere.

(3) Credit shall be granted only to the extent necessary to meet the applicable categorical Pretreatment Standard(s), up to a maximum value equal to the influent value. Additional monitoring may be necessary to determine eligibility for credits and compliance with Standard(s) adjusted under this section.

(4) Credit shall be granted only if the User demonstrates that the intake water is drawn from the same body of water as that into which the POTW discharges. The Control Authority may waive this requirement if it finds that no environmental degradation will result.

(c) The applicable categorical pretreatment standards contained in 40 CFR subchapter N specifically provide that they shall be applied on a net basis.

[53 FR 40614, Oct. 17, 1988, as amended at 58 FR 18017, Apr. 7, 1993]

§ 403.16 Upset provision.

(a) *Definition.* For the purposes of this section, *Upset* means an exceptional incident in which there is unintentional and temporary noncompliance with categorical Pretreatment Standards because of factors beyond the reasonable control of the Industrial User. An Upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

(b) *Effect of an upset.* An Upset shall constitute an affirmative defense to an action brought for noncompliance with categorical Pretreatment Standards if the requirements of paragraph (c) are met.

(c) *Conditions necessary for a demonstration of upset.* An Industrial User who wishes to establish the affirmative defense of Upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An Upset occurred and the Industrial User can identify the cause(s) of the Upset;

(2) The facility was at the time being operated in a prudent and workmanlike manner and in compliance with applicable operation and maintenance procedures;

(3) The Industrial User has submitted the following information to the POTW and Control Authority within 24 hours of becoming aware of the Upset (if this information is provided orally, a written submission must be provided within five days):

(i) A description of the Indirect Discharge and cause of noncompliance;

(ii) The period of noncompliance, including exact dates and times or, if not corrected, the anticipated time the noncompliance is expected to continue;

(iii) Steps being taken and/or planned to reduce, eliminate and prevent recurrence of the noncompliance.

(d) *Burden of proof.* In any enforcement proceeding the Industrial User seeking to establish the occurrence of an Upset shall have the burden of proof.

(e) *Reviewability of agency consideration of claims of upset.* In the usual exercise of prosecutorial discretion, Agency enforcement personnel should review any claims that non-compliance was caused by an Upset. No determinations made in the course of the review constitute final Agency action subject to judicial review. Industrial Users will have the opportunity for a judicial determination on any claim of Upset only in an enforcement action brought for noncompliance with categorical Pretreatment Standards.

(f) *User responsibility in case of upset.* The Industrial User shall control production or all Discharges to the extent necessary to maintain compliance with categorical Pretreatment Standards upon reduction, loss, or failure of its treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost or fails.

[46 FR 9439, Jan. 28, 1981, as amended at 53 FR 40615, Oct. 17, 1988]

§ 403.17 Bypass.

(a) *Definitions.* (1) *Bypass* means the intentional diversion of wastestreams

Environmental Protection Agency

§ 403.18

from any portion of an Industrial User's treatment facility.

(2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

(b) *Bypass not violating applicable Pretreatment Standards or Requirements.* An Industrial User may allow any bypass to occur which does not cause Pretreatment Standards or Requirements to be violated, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of paragraphs (c) and (d) of this section.

(c) *Notice.* (1) If an Industrial User knows in advance of the need for a bypass, it shall submit prior notice to the Control Authority, if possible at least ten days before the date of the bypass.

(2) An Industrial User shall submit oral notice of an unanticipated bypass that exceeds applicable Pretreatment Standards to the Control Authority within 24 hours from the time the Industrial User becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Industrial User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The Control Authority may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

(d) *Prohibition of bypass.* (1) Bypass is prohibited, and the Control Authority may take enforcement action against an Industrial User for a bypass, unless;

(i) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

(ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, reten-

tion of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and

(iii) The Industrial User submitted notices as required under paragraph (c) of this section.

(2) The Control Authority may approve an anticipated bypass, after considering its adverse effects, if the Control Authority determines that it will meet the three conditions listed in paragraph (d)(1) of this section.

[53 FR 40615, Oct. 17, 1988, as amended at 58 FR 18017, Apr. 7, 1993]

§ 403.18 Modification of POTW pretreatment programs.

(a) *General.* Either the Approval Authority or a POTW with an approved POTW Pretreatment Program may initiate program modification at any time to reflect changing conditions at the POTW. Program modification is necessary whenever there is a significant change in the operation of a POTW Pretreatment Program that differs from the information in the POTW's submission, as approved under § 403.11.

(b) *Substantial modifications defined.* Substantial modifications include:

(1) Modifications that relax POTW legal authorities (as described in § 403.8(f)(1)), except for modifications that directly reflect a revision to this Part 403 or to 40 CFR chapter I, subchapter N, and are reported pursuant to paragraph (d) of this section;

(2) Modifications that relax local limits, except for the modifications to local limits for pH and reallocations of the Maximum Allowable Industrial Loading of a pollutant that do not increase the total industrial loadings for the pollutant, which are reported pursuant to paragraph (d) of this section. Maximum Allowable Industrial Loading means the total mass of a pollutant that all Industrial Users of a POTW (or