

Environmental Protection Agency

§ 420.26

(b) The following standards apply with respect to each new source that commences construction after November 18, 2002.

(1) *Sintering operations with wet air pollution control system.* The following table presents NSPS for sintering operations with wet air pollution control systems:

SUBPART B—NEW SOURCE PERFORMANCE STANDARDS (NSPS)

Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
TSS	0.0200	0.00751
O&G	0.00501	
Ammonia-N ²	0.0150	0.00501
Cyanide ²	0.00100	0.000501
Phenols (4AAP) ²	0.000100	0.0000501
TRC ³	0.000250	
Lead	0.000451	0.000150
Zinc	0.000676	0.000225
pH	(⁴)	(⁴)
2,3,7,8-TCDF	<ML	

¹ Pounds per thousand lb of product.
² Limits for these parameters apply only when sintering wastewater is co-treated with ironmaking wastewater.
³ Applicable only when sintering process wastewater is chlorinated.
⁴ Within the range of 6.0 to 9.0.

(2) *Sintering operations with dry air pollution control system.* There shall be no discharge of process wastewater pollutants to waters of the U.S.

to this subpart that introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and must achieve the following pretreatment standards for existing sources (PSES):

[67 FR 64265, Oct. 17, 2002]

§ 420.25 Pretreatment standards for existing sources (PSES).

(a) Sintering operations with wet air pollution control system. The following table presents PSES for sintering operations with wet air pollution control systems:

Except as provided in 40 CFR 403.7 and 403.13, any existing source subject

SUBPART B—PRETREATMENT STANDARDS FOR EXISTING SOURCES (PSES)

Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
Ammonia-N ^{2,3}	0.0150	0.00501
Cyanide ²	0.00300	0.00150
Phenols (4AAP) ²	0.000100	0.0000501
Lead	0.000451	0.000150
Zinc	0.000676	0.000225
2,3,7,8-TCDF	<ML	

¹ Pounds per thousand lb of product.
² The pretreatment standards for these parameters apply only when sintering wastewater is co-treated with ironmaking wastewater.
³ The pretreatment standards for ammonia are not applicable to sources that discharge to a POTW with nitrification capability (defined at § 420.02(s)).

(b) *Sintering operations with dry air pollution control system.* There shall be no discharge of process wastewater pollutants to POTWs.

licly owned treatment works must comply with 40 CFR part 403 and must achieve the following pretreatment standards for new sources (PSNS), as applicable.

[67 FR 64265, Oct. 17, 2002]

§ 420.26 Pretreatment standards for new sources (PSNS).

(a) Sintering operations with wet air pollution control system.

Except as provided in 40 CFR 403.7, any new source subject to this subpart that introduces pollutants into a pub-

(1) Any new source subject to the provisions of this section that commenced discharging after November 19, 2012 and before November 18, 2002 must