

§ 423.10

40 CFR Ch. I (7-1-03 Edition)

423.14 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT). [Reserved]

423.15 New source performance standards (NSPS).

423.16 Pretreatment standards for existing sources (PSES).

423.17 Pretreatment standards for new sources (PSNS).

APPENDIX A TO PART 423—126 PRIORITY POLLUTANTS

AUTHORITY: Secs. 301; 304(b), (c), (e), and (g); 306(b) and (c); 307(b) and (c); and 501, Clean Water Act (Federal Water Pollution Control Act Amendments of 1972, as amended by Clean Water Act of 1977) (the "Act"; 33 U.S.C. 1311; 1314(b), (c), (e), and (g); 1316(b) and (c); 1317(b) and (c); and 1361; 86 Stat. 816, Pub. L. 92-500; 91 Stat. 1567, Pub. L. 95-217), unless otherwise noted.

SOURCE: 47 FR 52304, Nov. 19, 1982, unless otherwise noted.

§ 423.10 Applicability.

The provisions of this part are applicable to discharges resulting from the operation of a generating unit by an establishment primarily engaged in the generation of electricity for distribution and sale which results primarily from a process utilizing fossil-type fuel (coal, oil, or gas) or nuclear fuel in conjunction with a thermal cycle employing the steam water system as the thermodynamic medium.

§ 423.11 Specialized definitions.

In addition to the definitions set forth in 40 CFR part 401, the following definitions apply to this part:

(a) The term *total residual chlorine* (or total residual oxidants for intake water with bromides) means the value obtained using the amperometric method for total residual chlorine described in 40 CFR part 136.

(b) The term *low volume waste sources* means, taken collectively as if from one source, wastewater from all sources except those for which specific limitations are otherwise established in this part. Low volume wastes sources include, but are not limited to: wastewaters from wet scrubber air pollution control systems, ion exchange water treatment system, water treatment evaporator blowdown, laboratory and sampling streams, boiler blowdown, floor drains, cooling tower basin

cleaning wastes, and recirculating house service water systems. Sanitary and air conditioning wastes are not included.

(c) The term *chemical metal cleaning waste* means any wastewater resulting from the cleaning of any metal process equipment with chemical compounds, including, but not limited to, boiler tube cleaning.

(d) The term *metal cleaning waste* means any wastewater resulting from cleaning [with or without chemical cleaning compounds] any metal process equipment including, but not limited to, boiler tube cleaning, boiler fireside cleaning, and air preheater cleaning.

(e) The term *fly ash* means the ash that is carried out of the furnace by the gas stream and collected by mechanical precipitators, electrostatic precipitators, and/or fabric filters. Economizer ash is included when it is collected with fly ash.

(f) The term *bottom ash* means the ash that drops out of the furnace gas stream in the furnace and in the economizer sections. Economizer ash is included when it is collected with bottom ash.

(g) The term *once through cooling water* means water passed through the main cooling condensers in one or two passes for the purpose of removing waste heat.

(h) The term *recirculated cooling water* means water which is passed through the main condensers for the purpose of removing waste heat, passed through a cooling device for the purpose of removing such heat from the water and then passed again, except for blowdown, through the main condenser.

(i) The term *10 year, 24/hour rainfall event* means a rainfall event with a probable recurrence interval of once in ten years as defined by the National Weather Service in Technical Paper No. 40, *Rainfall Frequency Atlas of the United States*, May 1961 or equivalent regional rainfall probability information developed therefrom.

(j) The term *blowdown* means the minimum discharge of recirculating water for the purpose of discharging materials contained in the water, the further buildup of which would cause concentration in amounts exceeding