

## § 200.927

for exterior walls. Overhanging eaves, cornices, and ridges, 40 psf upward normal to roof surface. These local pressures shall not be included with the design pressure when computing overall loads. The pressures shall be applied perpendicularly outward on strips of width equal to 10 percent of the least width of building. Net uplift on horizontal projection of roof shall not be less than 12 psf.

(2) *Severe wind design pressures.* If the construction is higher than 30 ft., or if it is located in an area experiencing wind speeds greater than 80 mph, higher design wind pressures than shown above are required. Use Section 6 of ASCE 7-88 for higher criteria and for determining where wind speeds greater than 80 mph occur. Pressures are assumed to act horizontally on the gross area of the vertical projection of the structure except as noted for roof design.

(d) Seismic conditions shall be in accordance with Section 9 of ASCE 7-88.

(e) *Subject to damage from: weathering.* A jurisdiction's weathering region shall be as established by the map in ASTM C 62-83.

(f) *Subject to damage from: frost line depth.* Exterior wall footings or foundation walls including those of accessory buildings shall extend a minimum of 6 in. below the finished grade and, where applicable, the prevailing frost line.

(g) *Subject to damage from: termites.* "Yes" shall be used in locations designated as Regions I, II or III. "No" shall be used in locations designated as Region IV. The map for Termite Infestation Probability in appendix A of CABO, One and Two Family Dwelling Code shall be used to determine the jurisdiction's region.

(h) *Subject to damage from: decay.* "Yes" shall be used in locations designated as moderate to severe and slight to moderate. "No" shall be used in locations designated as none to slight. The Decay Probability map in appendix A of CABO, One and Two Family Dwelling Code shall be used to determine the jurisdiction's decay designation.

(Approved by the Office of Management and Budget under control number 2502-0338)

[50 FR 39599, Sept. 27, 1985, as amended at 59 FR 36695, July 19, 1994]

## 24 CFR Ch. II (4-1-04 Edition)

### § 200.927 Incorporation by reference of minimum property standards.

The Minimum Property Standards as contained in the handbooks identified in §200.929(b) are incorporated by reference into this section as though set forth in full in accordance with 5 U.S.C. 552(a) and 1 CFR part 51.

[50 FR 39592, Sept. 29, 1985]

### § 200.929 Description and identification of minimum property standards.

(a) *Description.* The Minimum Property Standards describe physical standards for housing. They are intended to provide a sound basis for determining the acceptability of housing built under the HUD mortgage insurance and low-rent public housing programs. The Minimum Property Standards refer to material standards developed by industry and accepted by HUD. In addition, under Section 521 of the National Housing Act, HUD adopts its own technical suitability standards for materials and products for which there are no industry standards acceptable to HUD. These standards are contained in Use of Materials Bulletins that apply to products and methods and Materials Releases that apply to specific materials. Use of Materials Bulletins and Materials Releases are addenda to the Minimum Property Standards. Unless otherwise stated, the current edition, issue, or version of each of these documents, as available from its source, is applicable to this subpart S. A list of the Use of Materials Bulletins, Materials Releases, and MPS Appendix listing the applicable referenced Standards may be obtained from the Construction Standards Division, Office of Manufactured Housing and Construction Standards, room 6170 Department of Housing and Urban Development, 451 7th Street, SW, Washington, DC 20410.

(b) *Identification.* The Minimum Property Standards have been published as described below:

(1) MPS for One and Two Family Dwellings. See §§ 200.926, 200.926 (a) through (e).

(2) MPS for Housing 4910.1, 1994 edition. This volume applies to buildings and sites designed and used for normal multifamily occupancy, including both unsubsidized and subsidized insured

housing, and to care-type housing insured under the National Housing Act. It also includes, in Appendix K, a reprint of the MPS for One and Two Family Dwellings identified in paragraph (b)(1) of this section.

[39 FR 26895, July 24, 1974, as amended at 42 FR 33890, July 1, 1977; 47 FR 29524, July 7, 1982; 47 FR 35761, Aug. 17, 1982; 49 FR 18695, May 1, 1984; 50 FR 39592, Sept. 29, 1985; 51 FR 28699, Aug. 11, 1986; 58 FR 60250, Nov. 15, 1993; 63 FR 5423, Feb. 2, 1998]

**§ 200.929a Fair Housing Accessibility Guidelines.**

Builders and developers may use the Department's Fair Housing Accessibility Guideline when designing or constructing covered multifamily dwelling units in order to comply with the Fair Housing Act. The Guidelines may be found in the 24 CFR Chapter I, Subchapter A, Appendix II, titled Fair Housing Accessibility Guidelines—Design Guidelines for Accessible/Adaptable Dwellings.

[58 FR 60250, Nov. 15, 1993]

**§ 200.931 Statement of availability.**

(a) Updated copies of the Minimum Property Standards and Use of Materials Bulletins are available for public examination in the Office of Consumer and Regulatory Affairs, Department of Housing and Urban Development, room 9156, 451 Seventh St. SW., Washington, D.C. 20410-8000. In addition, copies of volumes 1, 2, and 3 of the Minimum Property Standards may be purchased from the U.S. Government Printing Office, Washington, D.C. 20402.

(b) Publications approved by the Director of the Federal Register for incorporation by reference in accordance with 5 U.S.C. 552(a) and 1 CFR part 51 are available for inspection at the Office of the Federal Register, 800 North Capitol Street, NW., Suite 700, Washington, D.C.

[63 FR 5423, Feb. 2, 1998]

**§ 200.933 Changes in minimum property standards.**

Changes in the Minimum Property Standards will generally be made every three years. Changes will be made in accordance with HUD policy for the adoption of rules and regulations set

forth in part 10 of this title. Notice of such changes will be published in the FEDERAL REGISTER. As the changes are made, they will be incorporated into the volumes of the Minimum Property Standards to which they apply. The volumes available for public examination and for purchase will contain all changes up to the date of examination or purchase. An official, historic file of such changes will be available in the office of the Rules Docket Clerk in the HUD Central Office in Washington, DC, and in each HUD Regional, Area, and Insuring Office. A similar copy of the standards will also be maintained in the Office of the Federal Register, Washington, DC.

[39 FR 26895, July 24, 1974, as amended at 58 FR 60250, Nov. 15, 1993]

**§ 200.934 User fee system for the technical suitability of products program.**

(a) *General.* This section establishes fee requirements for the issuance of Structural Engineering Bulletins (SEBs), Mechanical Engineering Bulletins (MEBs), Truss Connector Bulletins (TCBs), Area Letters of Acceptance (ALAs), Materials Releases (MRs), and review of program administrator applications submitted pursuant to § 200.935 of this title.

(b) *Filing address*—(1) *Applications containing payment.* When applications for or correspondence concerning SEBs, MEBs, TCBs, MRs, or program administrator approval contain payment, such applications or correspondence shall be sent to the following address:

U.S. Department of Housing and Urban Development, Technical Suitability of Product Fees, P.O. Box 954199, St. Louis, MO. 63195-4199.

(2) *Other correspondence.* All other correspondence concerning SEBs, MEBs, TCBs, MRs, and program administrator acceptance shall be sent to the following address:

Manufactured Housing and Construction Standards Division, Department of Housing and Urban Development, 451 Seventh Street, SW., Attn: Mail Room B-133, Washington, DC 20410.

(3) *Application for ALAs.* Applications for or correspondence concerning ALAs