

(i) Manufacturer's statement of conformance to UM 73a;

(ii) Manufacturer's name and code identifying the plant location.

(2) The certification label shall be affixed to each plastic bathroom fixture.

(c) *Periodic tests and quality control inspections.* Under the procedures set forth in paragraph (d)(8) of §200.935, concerning periodic tests and quality control inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of plastic bathroom fixtures, testing and inspection shall be conducted as follows:

(1) At least every six months, the administrator shall visit the manufacturer's facility to select a sample of each certified plastic bathtub unit, plastic shower receptor and stall, plastic water closet bowl and tank for testing in an approved laboratory, in accordance with applicable standards.

(2) At least every twelve months, the administrator shall visit the manufacturer's facility to select a sample of each certified plastic lavatory for testing in accordance with applicable standards.

(3) The administrator shall also review quality control procedures at each visit to determine that they continue to be followed.

[49 FR 378, Jan. 4, 1984, as amended at 59 FR 36695, July 19, 1994]

**§ 200.940 Supplementary specific requirements under the HUD building product standards and certification program for sealed insulating glass units.**

(a) *Applicable standards.* (1) All sealed insulating glass units shall be designed, manufactured, and tested in compliance with the American Society for Testing and Materials standard: ASTM E-774-92 Standard Specification for Sealed Insulating Glass Units.

(2) This standard has been approved by the Director of the Federal Register for incorporation by reference. The standard is available from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103. This standard is also available for inspection at the Office of the Federal Register, 800 North Capitol Street,

NW., 7th Floor, suite 700, Washington, DC.

(b) *Labeling.* Under the procedures set forth in §200.935(d)(6) concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standards are issued by the administrator to the manufacturer. Each sealed insulating glass unit shall be marked as conforming to UM 82a. The label shall be located on each sealed insulating unit so that it is available for inspection. The label shall include the manufacturer's name and plant location.

(c) *Periodic tests and quality assurance inspections.* Under the procedures set forth in §200.935(d)(8) concerning periodic tests and quality assurance inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of sealed insulating glass units, testing and inspection shall be conducted as follows:

(1) At least once a year, the administrator shall visit the manufacturer's facility to select a sample, of the maximum size commercially available, for testing in a laboratory approved by the administrator.

(2) The administrator shall also review the quality assurance procedures twice a year to assure that they are being followed by the manufacturer.

[58 FR 67674, Dec. 22, 1993]

**§ 200.942 Supplementary specific procedural requirements under HUD building product standards and certification program for carpet and carpet with attached cushion.**

(a) *Applicable standards.* (1) Carpet and carpet with attached cushion certified for this program shall be designed, manufactured and tested in accordance with the following standards:

(i) AATCC 20A-81—Fiber Analysis: Quantitative;

(ii) AATCC 16E-82—Colorfastness to Light: Water-Cooled Xenon-Arc Lamp, Continuous Light;

(iii) AATCC 8-85—Colorfastness to Crocking: AATCC Crockmeter Method;

(iv) AATCC 24-85—Insect, Resistance to Textiles to;