

§ 35.1345

paint and visible dust, debris, residue or paint chips;

(iv) The results of the analysis of dust samples, in $\mu\text{g}/\text{sq. ft.}$, by location of sample; and

(v) The name and address of each laboratory that conducted the analysis of the dust samples, including the identification number for each such laboratory recognized by EPA under section 405(b) of the Toxic Substances Control Act (15 U.S.C. 2685(b)).

(3) The following information on the hazard reduction or maintenance activity for which clearance was performed:

(i) The start and completion dates of the hazard reduction or maintenance activity;

(ii) The name and address of each firm or organization conducting the hazard reduction or maintenance activity and the name of each supervisor assigned;

(iii) A detailed written description of the hazard reduction or maintenance activity, including the methods used, locations of exterior surfaces, interior rooms, common areas, and/or components where the hazard reduction activity occurred, and any suggested monitoring of encapsulants or enclosures; and

(iv) If soil hazards were reduced, a detailed description of the location(s) of the hazard reduction activity and the method(s) used.

(d) *Standards.* The clearance standards in §35.1320(b)(2) shall apply. If test results equal or exceed the standards, the dwelling unit, worksite, or common area represented by the sample fails the clearance examination.

(e) *Clearance failure.* All surfaces represented by a failed clearance sample shall be re-cleaned or treated by hazard reduction, and retested, until the applicable clearance level in §35.1320(b)(2) is met.

(f) *Independence.* Clearance examinations shall be performed by persons or entities independent of those performing hazard reduction or maintenance activities, unless the designated party uses qualified in-house employees to conduct clearance. An in-house employee shall not conduct both a hazard reduction or maintenance activity and its clearance examination.

24 CFR Subtitle A (4-1-04 Edition)

(g) *Worksite clearance.* When clearance is of an interior worksite, not an entire dwelling unit or residential property, dust samples taken for paragraph (b) of this section shall be taken from the floor and window (if available) to represent the area within the dust containment area. Clearance is not required if maintenance or hazard reduction activities in the worksite do not disturb painted surfaces of a total area more than that set forth in §35.1350(d)

§ 35.1345 Occupant protection and worksite preparation.

This section establishes procedures for protecting dwelling unit occupants and the environment from contamination from lead-contaminated or lead-containing materials during hazard reduction activities.

(a) *Occupant protection.* (1) Occupants shall not be permitted to enter the worksite during hazard reduction activities (unless they are employed in the conduct of these activities at the worksite), until after hazard reduction work has been completed and clearance, if required, has been achieved.

(2) Occupants shall be temporarily relocated before and during hazard reduction activities to a suitable, decent, safe, and similarly accessible dwelling unit that does not have lead-based paint hazards, except if:

(i) Treatment will not disturb lead-based paint, dust-lead hazards or soil-lead hazards;

(ii) Only the exterior of the dwelling unit is treated, and windows, doors, ventilation intakes and other openings in or near the worksite are sealed during hazard control work and cleaned afterward, and entry free of dust-lead hazards, soil-lead hazards, and debris is provided;

(iii) Treatment of the interior will be completed within one period of 8-day-time hours, the worksite is contained so as to prevent the release of leaded dust and debris into other areas, and treatment does not create other safety, health or environmental hazards (e.g., exposed live electrical wiring, release of toxic fumes, or on-site disposal of hazardous waste); or

(iv) Treatment of the interior will be completed within 5 calendar days, the worksite is contained so as to prevent

the release of leaded dust and debris into other areas, treatment does not create other safety, health or environmental hazards; and, at the end of work on each day, the worksite and the area within at least 10 feet (3 meters) of the containment area is cleaned to remove any visible dust or debris, and occupants have safe access to sleeping areas, and bathroom and kitchen facilities.

(3) The dwelling unit and the worksite shall be secured against unauthorized entry, and occupants' belongings protected from contamination by dust-lead hazards and debris during hazard reduction activities. Occupants' belongings in the containment area shall be relocated to a safe and secure area outside the containment area, or covered with an impermeable covering with all seams and edges taped or otherwise sealed.

(b) *Worksite preparation.* (1) The worksite shall be prepared to prevent the release of leaded dust, and contain lead-based paint chips and other debris from hazard reduction activities within the worksite until they can be safely removed. Practices that minimize the spread of leaded dust, paint chips, soil and debris shall be used during worksite preparation.

(2) A warning sign shall be posted at each entry to a room where hazard reduction activities are conducted when occupants are present; or at each main and secondary entryway to a building from which occupants have been relocated; or, for an exterior hazard reduction activity, where it is easily read 20 feet (6 meters) from the edge of the hazard reduction activity worksite. Each warning sign shall be as described in 29 CFR 1926.62(m), except that it shall be posted irrespective of employees' lead exposure and, to the extent practicable, provided in the occupants' primary language.

§ 35.1350 Safe work practices.

(a) *Prohibited methods.* Methods of paint removal listed in § 35.140 shall not be used.

(b) *Occupant protection and worksite preparation.* Occupants and their belongings shall be protected, and the worksite prepared, in accordance with § 35.1345.

(c) *Specialized cleaning.* After hazard reduction activities have been completed, the worksite shall be cleaned using cleaning methods, products, and devices that are successful in cleaning up dust-lead hazards, such as a HEPA vacuum or other method of equivalent efficacy, and lead-specific detergents or equivalent.

(d) *De minimis levels.* Safe work practices are not required when maintenance or hazard reduction activities do not disturb painted surfaces that total more than:

(1) 20 square feet (2 square meters) on exterior surfaces;

(2) 2 square feet (0.2 square meters) in any one interior room or space; or

(3) 10 percent of the total surface area on an interior or exterior type of component with a small surface area. Examples include window sills, baseboards, and trim.

§ 35.1355 Ongoing lead-based paint maintenance and reevaluation activities.

(a) *Maintenance.* Maintenance activities shall be conducted in accordance with paragraphs (a)(2)-(6) of this section, except as provided in paragraph (a)(1) of this section.

(1) Maintenance activities need not be conducted in accordance with this section if both of the following conditions are met, as applicable:

(i) Either a lead-based paint inspection indicates that no lead-based paint is present in the dwelling units, common areas, and on exterior surfaces, or a clearance report prepared in accordance with § 35.1340(a) indicates that all lead-based paint has been removed; and

(ii) If a risk assessment is required by the applicable subpart of this part, a current risk assessment indicates that no soil-lead hazards and no dust-lead hazards are present.

(2) A visual assessment for deteriorated paint, bare soil, and the failure of any hazard reduction measures shall be performed at unit turnover and every twelve months.

(3) (i) *Deteriorated paint.* All deteriorated paint on interior and exterior surfaces located on the residential property shall be stabilized in accordance with § 35.1330(a)(b), except for any