

TABLE 145.10(A)—PORTABLE AND SEMI-PORTABLE EXTINGUISHERS—Continued

Space	Classification	Quantity and location
MACHINERY SPACES		
Gas-fired boilers .....	B-II (CO <sub>2</sub> or dry chemical).	2 required.
Gas-fired boilers .....	B-V .....	1 required. <sup>1</sup>
Oil-fired boilers .....	B-II .....	2 required.
Oil-fired boilers .....	B-V .....	2 required. <sup>1</sup>
Internal combustion or gas turbine engines .....	B-II .....	1 for each engine. <sup>2</sup>
Electric motors or generators of open type .....	C-II .....	1 for each 2 motors or generators. <sup>3</sup>

<sup>1</sup> Not required where a fixed carbon dioxide system is installed.

<sup>2</sup> When installation is on weather deck or open to atmosphere at all times 1 B-II for each three engines is allowable.

<sup>3</sup> Small electrical appliances, such as fans, etc., shall not be counted or used as basis for determining number of extinguishers required.

[CGFR 56-4, 21 FR 903, Feb. 9, 1956]

**PART 146—OPERATIONS**

SOURCE: CGD 78-160, 47 FR 9383, Mar. 4, 1982, unless otherwise noted.

**Subpart A—OCS Facilities**

**Subpart A—OCS Facilities**

Sec.

- 146.1 Applicability.
- 146.5 Person in charge.
- 146.10 Notice of new facilities.
- 146.15 Maintenance of emergency equipment.
- 146.20 Work vests.
- 146.30 Notice of casualties.
- 146.35 Written report of casualty.
- 146.40 Diving casualties.
- 146.45 Pollution incidents.

**§ 146.1 Applicability.**

The provisions of this subpart apply to OCS facilities except mobile offshore drilling units.

**§ 146.5 Person in charge.**

(a) The owner or operator, or the agent of either of them, shall designate by title and in order of succession the persons on each OCS facility who shall be the “person in charge.”

(b) In case an emergency arises, nothing in the regulations in this subchapter shall be so construed as preventing the person in charge from pursuing the most effective action in that person’s judgement for rectifying the conditions causing the emergency.

**Subpart B—Manned OCS Facilities**

- 146.101 Applicability.
- 146.105 General alarm system.
- 146.110 Emergency signals.
- 146.115 Duties of personnel during an emergency.
- 146.120 Manning of survival craft.
- 146.125 Emergency drills.
- 146.130 Station bill.
- 146.135 Markings for emergency equipment.
- 146.140 Emergency Evacuation Plan.

**§ 146.10 Notice of new facilities.**

(a) The owner or operator of each OCS facility not in operation before April 5, 1982 shall, at least 30 days before the date on-site construction of the facility is expected to commence, notify the District Commander for the area in which the facility will be located of:

**Subpart C—Mobile Offshore Drilling Units**

- 146.201 Applicability.
- 146.202 Notice of arrival or relocation of MODUs on the OCS.
- 146.203 Requirements for U.S. and undocumented MODUs.
- 146.205 Requirements for foreign MODUs.
- 146.210 Emergency Evacuation Plan.

(1) The position in which the facility will be operated;

(2) The designation assigned to the facility for identification under 30 CFR 250.37;

(3) The date when operation of the facility is expected to commence; and

**Subpart D—Vessels**

- 146.301 Applicability.
- 146.303 Notice and written report of casualties.

AUTHORITY: 43 U.S.C. 1333(d)(1), 1348(c), 1356; 49 CFR 1.46.