

§ 150.521

§ 150.521 What records are required?

(a) The operator must maintain a record of each test and inspection under § 150.520 on the deepwater port (or in the operator's principal office, in the case of an unmanned deepwater port) for at least 2 years.

(b) The record must show:

- (1) The date of each test and inspection;
- (2) The number or other identification of each fire extinguisher or system tested or inspected; and
- (3) The name of the person who conducted the test or inspection and the name of the company that person represents.

MISCELLANEOUS OPERATIONS

§ 150.530 What may the fire-main system be used for?

The fire-main system may be used only for firefighting and for deck washing, unless it is capable of being isolated and can provide the applicable minimum pressures required outlined in § 149.416 of this chapter.

§ 150.531 How many fire pumps must be kept ready for use at all times?

At least one of the fire pumps required by this subchapter must be kept ready for use at all times.

§ 150.532 What are the requirements for connection and stowage of fire hoses?

(a) At least one length of fire-hose, with a combination nozzle, must be connected to each fire hydrant at all times. If in a location exposed to the weather, the fire-hose may be removed from the hydrant during freezing weather.

(b) When not in use, fire-hose connected to a fire hydrant must be stowed on a hose rack.

(c) The hydrant nearest the edge of a deck must have enough lengths of fire-hose connected to it to allow 10 feet of hose, when pressurized, to curve over the edge.

§ 150.540 What are the restrictions on fueling aircraft?

If the deepwater port is not equipped with a permanent fueling facility, the

33 CFR Ch. I (7-1-04 Edition)

COTP's approval is necessary before aircraft may be fueled at the port.

§ 150.550 What are the requirements for the muster list?

(a) A muster list must be posted on each pumping platform complex.

(b) The muster list must:

- (1) List the name and title of each person, in order of succession, who is the person in charge of the pumping platform complex for purposes of supervision during an emergency;
- (2) List the special duties and duty stations for each person on the pumping platform complex in the event of an emergency that requires the use of equipment covered by part 149 of this chapter; and
- (3) Identify the signals for calling persons to their emergency stations and for abandoning the pumping platform complex.

§ 150.555 How must cranes be maintained?

Cranes must be operated, maintained, and tested in accordance with subpart F to 46 CFR part 109.

Subpart G—Workplace Safety and Health

§ 150.600 What does this subpart do?

This subpart concerns requirements for workplace safety and health on a deepwater port.

SAFETY AND HEALTH (GENERAL)

§ 150.601 What are the requirements for workplace safety and health on a deepwater port?

(a) Each operator of a deepwater port must ensure compliance, on that port, with the requirements of this subpart, and must ensure that all places of employment within the port are:

- (1) Maintained in compliance with workplace safety and health regulations of this subpart; and
- (2) Free from recognized hazardous conditions.

(b) Persons responsible for actual operations, including owners, operators, contractors, and subcontractors must ensure that those operations subject to their control are: