

Corresponding requirement	Description of information to report	Frequency
(b) Individual Filter Turbidity Requirements (§§ 141.560–141.564).	(2) The filter number(s), corresponding date(s), and the turbidity value(s) which exceeded 1.0 NTU during the month, and the cause (if known) for the exceedance(s), but only if 2 consecutive measurements exceeded 1.0 NTU.	By the 10th of the following month.

**§ 141.571 What records does subpart T require my system to keep?**

Your system must keep several types of records based on the requirements of subpart T, in addition to recordkeeping requirements under §141.75. The following table describes the necessary records, the length of time these records must be kept, and for which requirement the records pertain. Your system is required to maintain records described in this table, if it is subject to the specific requirement shown in the first column.

Corresponding requirement	Description of necessary records	Duration of time records must be kept
(a) Individual Filter Turbidity Requirements (§§ 141.560–141.564)	Results of individual filter monitoring	At least 3 years.
(b) Disinfection Profiling (§§ 141.530–141.536)	Results of Profile (including raw data and analysis)	Indefinitely.
(c) Disinfection Benchmarking (§§ 141.540–141.544)	Benchmark (including raw data and analysis)	Indefinitely.

**PART 142—NATIONAL PRIMARY DRINKING WATER REGULATIONS IMPLEMENTATION**

**Subpart A—General Provisions**

- Sec.
- 142.1 Applicability.
- 142.2 Definitions.
- 142.3 Scope.
- 142.4 State and local authority.

**Subpart B—Primary Enforcement Responsibility**

- 142.10 Requirements for a determination of primary enforcement responsibility.
- 142.11 Initial determination of primary enforcement responsibility.
- 142.12 Revision of State programs.
- 142.13 Public hearing.
- 142.14 Records kept by States.
- 142.15 Reports by States.
- 142.16 Special primacy requirements.
- 142.17 Review of State programs and procedures for withdrawal of approved primacy programs.
- 142.18 EPA review of State monitoring determinations.
- 142.19 EPA review of State implementation of national primary drinking water regulations for lead and copper.

**Subpart C—Review of State-Issued Variances and Exemptions**

- 142.20 State-issued variances and exemptions under Section 1415(a) and Section 1416 of the Act.
- 142.21 State consideration of a variance or exemption request.
- 142.22 Review of State variances, exemptions and schedules.
- 142.23 Notice to State.
- 142.24 Administrator’s rescission.

**Subpart D—Federal Enforcement**

- 142.30 Failure by State to assure enforcement.
- 142.31 [Reserved]
- 142.32 Petition for public hearing.
- 142.33 Public hearing.
- 142.34 Entry and inspection of public water systems.

**Subpart E—Variances Issued by the Administrator Under Section 1415(a) of the Act**

- 142.40 Requirements for a variance.
- 142.41 Variance request.
- 142.42 Consideration of a variance request.
- 142.43 Disposition of a variance request.
- 142.44 Public hearings on variances and schedules.
- 142.45 Action after hearing.
- 142.46 Alternative treatment techniques.

§ 142.1

40 CFR Ch. I (7-1-04 Edition)

**Subpart F—Exemptions Issued by the Administrator**

- 142.50 Requirements for an exemption.
- 142.51 Exemption request.
- 142.52 Consideration of an exemption request.
- 142.53 Disposition of an exemption request.
- 142.54 Public hearings on exemption schedules.
- 142.55 Final schedule.
- 142.56 Extension of date for compliance.
- 142.57 Bottled water, point-of-use, and point-of-entry devices.

**Subpart G—Identification of Best Technology, Treatment Techniques or Other Means Generally Available**

- 142.60 Variances from the maximum contaminant level for total trihalomethanes.
- 142.61 Variances from the maximum contaminant level for fluoride.
- 142.62 Variances and exemptions from the maximum contaminant levels for organic and inorganic chemicals.
- 142.63 Variances and exemptions from the maximum contaminant level for total coliforms.
- 142.64 Variances and exemptions from the requirements of part 141, subpart H—Filtration and Disinfection.
- 142.65 Variances and exemptions from the maximum contaminant levels for radionuclides.

**Subpart H—Indian Tribes**

- 142.72 Requirements for Tribal eligibility.
- 142.76 Request by an Indian Tribe for a determination of eligibility.
- 142.78 Procedure for processing an Indian Tribe's application.

**Subpart I—Administrator's Review of State Decisions that Implement Criteria Under Which Filtration Is Required**

- 142.80 Review procedures.
- 142.81 Notice to the State.

**Subpart J [Reserved]**

**Subpart K—Variances for Small System**

GENERAL PROVISIONS

- 142.301 What is a small system variance?
- 142.302 Who can issue a small system variance?
- 142.303 Which size public water systems can receive a small system variance?
- 142.304 For which of the regulatory requirements is a small system variance available?
- 142.305 When can a small system variance be granted by a State?

REVIEW OF SMALL SYSTEM VARIANCE APPLICATION

- 142.306 What are the responsibilities of the public water system, State and the Administrator in ensuring that sufficient information is available and for evaluation of a small system variance application?
- 142.307 What terms and conditions must be included in a small system variance?

PUBLIC PARTICIPATION

- 142.308 What public notice is required before a State or the Administrator proposes to issue a small system variance?
- 142.309 What are the public meeting requirements associated with the proposal of a small system variance?
- 142.310 How can a person served by the public water system obtain EPA review of a State proposed small system variance?

EPA REVIEW AND APPROVAL OF SMALL SYSTEM VARIANCES

- 142.311 What procedures allow for the Administrator to object to a proposed small system variance or overturn a granted small system variance for a public water system serving 3,300 or fewer persons?
- 142.312 What EPA action is necessary when a State proposes to grant a small system variance to a public water system serving a population of more than 3,300 and fewer than 10,000 persons?
- 142.313 How will the Administrator review a State's program under this subpart?

AUTHORITY: 42 U.S.C. 300f, 300g-1, 300g-2, 300g-3, 300g-4, 300g-5, 300g-6, 300j-4, 300j-9, and 300j-11.

SOURCE: 41 FR 2918, Jan. 20, 1976, unless otherwise noted.

**Subpart A—General Provisions**

**§ 142.1 Applicability.**

This part sets forth, pursuant to sections 1413 through 1416, 1445, and 1450 of the Public Health Service Act, as amended by the Safe Drinking Water Act, Public Law 93-523, regulations for the implementation and enforcement of the national primary drinking water regulations contained in part 141 of this chapter.

**§ 142.2 Definitions.**

As used in this part, and except as otherwise specifically provided: *Act* means the Public Health Service Act.