

§ 35.2118

40 CFR Ch. I (7-1-04 Edition)

§ 35.2118 Preaward costs.

(a) EPA will not award grant assistance for Step 2+3 and Step 3 work performed before award of grant assistance for that project, except:

(1) In emergencies or instances where delay could result in significant cost increases, the Regional Administrator may approve preliminary building work (such as procurement of major equipment requiring long lead times, field testing of innovative and alternative technologies, minor sewer rehabilitation, acquisition of eligible land or an option for the purchase of eligible land or advance building on minor portions of treatment works) after completion of the environmental review as required by § 35.2113.

(2) If the Regional Administrator approves preliminary Step 3 work, such approval is not an actual or implied commitment of grant assistance and the applicant proceeds at its own risk.

(b) Any procurement is subject to the requirements of 40 CFR part 33, and in the case of acquisition of eligible real property, 40 CFR part 4.

(Approved by the Office of Management and Budget under control number 2040-0027)

[49 FR 6234, Feb. 17, 1984, as amended at 55 FR 27097, June 29, 1990]

§ 35.2120 Infiltration/Inflow.

(a) *General.* The applicant shall demonstrate to the Regional Administrator's satisfaction that each sewer system discharging into the proposed treatment works project is not or will not be subject to excessive infiltration/inflow. For combined sewers, inflow is not considered excessive in any event.

(b) *Inflow.* If the rainfall induced peak inflow rate results or will result in chronic operational problems during storm events, or the rainfall-induced total flow rate exceeds 275 gpcd during storm events, the applicant shall perform a study of the sewer system to determine the quantity of excessive inflow and to propose a rehabilitation program to eliminate the excessive inflow. All cases in which facilities are planned for the specific storage and/or treatment of inflow shall be subject to a cost-effectiveness analysis.

(c) *Infiltration.* (1) If the flow rate at the existing treatment facility is 120

gallons per capita per day or less during periods of high groundwater, the applicant shall build the project including sufficient capacity to transport and treat any existing infiltration. However, if the applicant believes any specific portion of its sewer system is subject to excessive infiltration, the applicant may confirm its belief in a cost-effectiveness analysis and propose a sewer rehabilitation program to eliminate that specific excessive infiltration.

(2) If the flow rate at the existing treatment facility is more than 120 gallons per capita per day during periods of high groundwater, the applicant shall either:

(i) Perform a study of the sewer system to determine the quantity of excessive infiltration and to propose a sewer rehabilitation program to eliminate the excessive infiltration; or

(ii) If the flow rate is not significantly more than 120 gallons per capita per day, request the Regional Administrator to determine that he may proceed without further study, in which case the allowable project cost will be limited to the cost of a project with a capacity of 120 gallons per capita per day under appendix A.G.2.a.

(Approved by the Office of Management and Budget under control number 2040-0027)

[49 FR 6234, Feb. 17, 1984, as amended at 50 FR 45895, Nov. 4, 1985]

§ 35.2122 Approval of user charge system and proposed sewer use ordinance.

If the project is for Step 3 grant assistance, unless it is solely for acquisition of eligible land, the applicant must obtain the Regional Administrator's approval of its user charge system (§ 35.2140) and proposed (or existing) sewer use ordinance § 35.2130). If the applicant has a sewer use ordinance or user charge system in affect, the applicant shall demonstrate to the Regional Administrator's satisfaction that they meet the requirements of this part and are being enforced.

(Approved by the Office of Management and Budget under control number 2040-0027)