

substance, as determined under paragraph (b) of this section and the provisions below, vaporizes resulting in a vapor cloud explosion. A yield factor of 10 percent of the available energy released in the explosion shall be used to determine the distance to the explosion endpoint if the model used is based on TNT equivalent methods.

(1) For regulated flammable substances that are normally liquids at ambient temperature, the owner or operator shall assume that the entire quantity in the vessel or pipe, as determined under paragraph (b) of this section, is spilled instantaneously to form a liquid pool. For liquids at temperatures below their atmospheric boiling point, the volatilization rate shall be calculated at the conditions specified in paragraph (d) of this section.

(2) The owner or operator shall assume that the quantity which becomes vapor in the first 10 minutes is involved in the vapor cloud explosion.

(g) *Parameters to be applied.* The owner or operator shall use the parameters defined in § 68.22 to determine distance to the endpoints. The owner or operator may use the methodology provided in the RMP Offsite Consequence Analysis Guidance or any commercially or publicly available air dispersion modeling techniques, provided the techniques account for the modeling conditions and are recognized by industry as applicable as part of current practices. Proprietary models that account for the modeling conditions may be used provided the owner or operator allows the implementing agency access to the model and describes model features and differences from publicly available models to local emergency planners upon request.

(h) *Consideration of passive mitigation.* Passive mitigation systems may be considered for the analysis of worst case provided that the mitigation system is capable of withstanding the release event triggering the scenario and would still function as intended.

(i) *Factors in selecting a worst-case scenario.* Notwithstanding the provisions of paragraph (b) of this section, the owner or operator shall select as the worst case for flammable regulated substances or the worst case for regulated toxic substances, a scenario based

on the following factors if such a scenario would result in a greater distance to an endpoint defined in § 68.22(a) beyond the stationary source boundary than the scenario provided under paragraph (b) of this section:

(1) Smaller quantities handled at higher process temperature or pressure; and

(2) Proximity to the boundary of the stationary source.

[61 FR 31718, June 20, 1996, as amended at 64 FR 28700, May 26, 1999]

§ 68.28 Alternative release scenario analysis.

(a) The number of scenarios. The owner or operator shall identify and analyze at least one alternative release scenario for each regulated toxic substance held in a covered process(es) and at least one alternative release scenario to represent all flammable substances held in covered processes.

(b) *Scenarios to consider.* (1) For each scenario required under paragraph (a) of this section, the owner or operator shall select a scenario:

(i) That is more likely to occur than the worst-case release scenario under § 68.25; and

(ii) That will reach an endpoint off-site, unless no such scenario exists.

(2) Release scenarios considered should include, but are not limited to, the following, where applicable:

(i) Transfer hose releases due to splits or sudden hose uncoupling;

(ii) Process piping releases from failures at flanges, joints, welds, valves and valve seals, and drains or bleeds;

(iii) Process vessel or pump releases due to cracks, seal failure, or drain, bleed, or plug failure;

(iv) Vessel overfilling and spill, or overpressurization and venting through relief valves or rupture disks; and

(v) Shipping container mishandling and breakage or puncturing leading to a spill.

(c) Parameters to be applied. The owner or operator shall use the appropriate parameters defined in § 68.22 to determine distance to the endpoints. The owner or operator may use either the methodology provided in the RMP Offsite Consequence Analysis Guidance

§ 68.30

or any commercially or publicly available air dispersion modeling techniques, provided the techniques account for the specified modeling conditions and are recognized by industry as applicable as part of current practices. Proprietary models that account for the modeling conditions may be used provided the owner or operator allows the implementing agency access to the model and describes model features and differences from publicly available models to local emergency planners upon request.

(d) Consideration of mitigation. Active and passive mitigation systems may be considered provided they are capable of withstanding the event that triggered the release and would still be functional.

(e) Factors in selecting scenarios. The owner or operator shall consider the following in selecting alternative release scenarios:

(1) The five-year accident history provided in § 68.42; and

(2) Failure scenarios identified under § 68.50 or § 68.67.

§ 68.30 Defining offsite impacts—population.

(a) The owner or operator shall estimate in the RMP the population within a circle with its center at the point of the release and a radius determined by the distance to the endpoint defined in § 68.22(a).

(b) *Population to be defined.* Population shall include residential population. The presence of institutions (schools, hospitals, prisons), parks and recreational areas, and major commercial, office, and industrial buildings shall be noted in the RMP.

(c) *Data sources acceptable.* The owner or operator may use the most recent Census data, or other updated information, to estimate the population potentially affected.

(d) *Level of accuracy.* Population shall be estimated to two significant digits.

§ 68.33 Defining offsite impacts—environment.

(a) The owner or operator shall list in the RMP environmental receptors within a circle with its center at the point of the release and a radius deter-

40 CFR Ch. I (7–1–04 Edition)

mined by the distance to the endpoint defined in § 68.22(a) of this part.

(b) Data sources acceptable. The owner or operator may rely on information provided on local U.S. Geological Survey maps or on any data source containing U.S.G.S. data to identify environmental receptors.

§ 68.36 Review and update.

(a) The owner or operator shall review and update the offsite consequence analyses at least once every five years.

(b) If changes in processes, quantities stored or handled, or any other aspect of the stationary source might reasonably be expected to increase or decrease the distance to the endpoint by a factor of two or more, the owner or operator shall complete a revised analysis within six months of the change and submit a revised risk management plan as provided in § 68.190.

§ 68.39 Documentation.

The owner or operator shall maintain the following records on the offsite consequence analyses:

(a) For worst-case scenarios, a description of the vessel or pipeline and substance selected as worst case, assumptions and parameters used, and the rationale for selection; assumptions shall include use of any administrative controls and any passive mitigation that were assumed to limit the quantity that could be released. Documentation shall include the anticipated effect of the controls and mitigation on the release quantity and rate.

(b) For alternative release scenarios, a description of the scenarios identified, assumptions and parameters used, and the rationale for the selection of specific scenarios; assumptions shall include use of any administrative controls and any mitigation that were assumed to limit the quantity that could be released. Documentation shall include the effect of the controls and mitigation on the release quantity and rate.

(c) Documentation of estimated quantity released, release rate, and duration of release.

(d) Methodology used to determine distance to endpoints.