

MODELS ACTUALLY TESTED AND NOT PREVIOUSLY IDENTIFIED—Continued

Rating of electric motor			Basic model(s) (model number(s))	Nominal full load efficiency
Motor power output (e.g. 1 hp or .75 kW)	Number of poles	Open or enclosed motor		
_____	_____	_____	_____	_____
Etc.	Etc.	Etc.	Etc.	Etc.

Subpart C [RESERVED]

TEST PROCEDURES

Subpart D—Commercial Warm Air Furnaces

§ 431.75 Materials incorporated by reference.

SOURCE: 69 FR 61939, Oct. 21, 2004, unless otherwise noted.

(a) We incorporate by reference the following test procedures into subpart D of Part 431. The Director of the Federal Register has approved the material listed in paragraph (b) of this section for incorporation by reference in accordance with 5 U.S.C. 552(a) and 1 CFR 51. Any subsequent amendment to this material by the standard-setting organization will not affect the DOE test procedures unless and until DOE amends its test procedures. We incorporate the material as it exists on the date of the approval and a notice of any change in the material will be published in the FEDERAL REGISTER.

§ 431.71 Purpose and scope.

This subpart contains energy conservation requirements for commercial warm air furnaces, pursuant to Part C of Title III of the Energy Policy and Conservation Act, as amended, 42 U.S.C. 6311-6316.

(b) *List of test procedures incorporated by reference.* (1) American National Standards Institute (ANSI) Standard Z21.47-1998, "Gas-Fired Central Furnaces," IBR approved for § 431.76.

§ 431.72 Definitions concerning commercial warm air furnaces.

The following definitions apply for purposes of this subpart D, and of subparts J through M of this part. Any words or terms not defined in this Section or elsewhere in this Part shall be defined as provided in Section 340 of the Act.

(2) Underwriters Laboratories (UL) Standard 727-1994, "Standard for Safety Oil-Fired Central Furnaces," IBR approved for § 431.76.

Commercial warm air furnace means a warm air furnace that is industrial equipment, and that has a capacity (rated maximum input) of 225,000 Btu per hour or more.

(3) Sections 8.2.2, 11.1.4, 11.1.5, and 11.1.6.2 of the Hydronics Institute (HI) Division of GAMA Boiler Testing Standard BTS-2000, "Method to Determine Efficiency of Commercial Space Heating Boilers," published January 2001 (HI BTS-2000), IBR approved for § 431.76.

Thermal efficiency for a commercial warm air furnace equals 100 percent minus percent flue loss determined using test procedures prescribed under § 431.76.

(4) Sections 7.2.2.4, 7.8, 9.2, and 11.3.7 of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) Standard 103-1993, "Method of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers," IBR approved for § 431.76.

Warm air furnace means a self-contained oil-fired or gas-fired furnace designed to supply heated air through ducts to spaces that require it and includes combination warm air furnace/electric air conditioning units but does not include unit heaters and duct furnaces.

(c) *Availability of references.* (1) *Inspection of test procedures.* The test procedures incorporated by reference are available for inspection at: