

**§ 71.35**

(4) Identification of the containment system;

(5) Specific materials of construction, weights, dimensions, and fabrication methods of—

(i) Receptacles;

(ii) Materials specifically used as nonfissile neutron absorbers or moderators;

(iii) Internal and external structures supporting or protecting receptacles;

(iv) Valves, sampling ports, lifting devices, and tie-down devices; and

(v) Structural and mechanical means for the transfer and dissipation of heat; and

(6) Identification and volumes of any receptacles containing coolant.

(b) With respect to the contents of the package—

(1) Identification and maximum radioactivity of radioactive constituents;

(2) Identification and maximum quantities of fissile constituents;

(3) Chemical and physical form;

(4) Extent of reflection, the amount and identity of nonfissile materials used as neutron absorbers or moderators, and the atomic ratio of moderator to fissile constituents;

(5) Maximum normal operating pressure;

(6) Maximum weight;

(7) Maximum amount of decay heat; and

(8) Identification and volumes of any coolants.

**§ 71.35 Package evaluation.**

The application must include the following:

(a) A demonstration that the package satisfies the standards specified in subparts E and F of this part;

(b) For a fissile material package, the allowable number of packages that may be transported in the same vehicle in accordance with § 71.59; and

(c) For a fissile material shipment, any proposed special controls and precautions for transport, loading, unloading, and handling and any proposed special controls in case of an accident or delay.

**§ 71.37 Quality assurance.**

(a) The applicant shall describe the quality assurance program (see Subpart H of this part) for the design, fab-

**10 CFR Ch. I (1–1–05 Edition)**

rication, assembly, testing, maintenance, repair, modification, and use of the proposed package.

(b) The applicant shall identify any specific provisions of the quality assurance program that are applicable to the particular package design under consideration, including a description of the leak testing procedures.

**§ 71.38 Renewal of a certificate of compliance or quality assurance program approval.**

(a) Except as provided in paragraph (b) of this section, each Certificate of Compliance or Quality Assurance Program Approval expires at the end of the day, in the month and year stated in the approval.

(b) In any case in which a person, not less than 30 days before the expiration of an existing Certificate of Compliance or Quality Assurance Program Approval issued pursuant to the part, has filed an application in proper form for renewal of either of those approvals, the existing Certificate of Compliance or Quality Assurance Program Approval for which the renewal application was filed shall not be deemed to have expired until final action on the application for renewal has been taken by the Commission.

(c) In applying for renewal of an existing Certificate of Compliance or Quality Assurance Program Approval, an applicant may be required to submit a consolidated application that incorporates all changes to its program that, are incorporated by reference in the existing approval or certificate, into as few referenceable documents as reasonably achievable.

**§ 71.39 Requirement for additional information.**

The Commission may at any time require additional information in order to enable it to determine whether a license, certificate of compliance, or other approval should be granted, renewed, denied, modified, suspended, or revoked.