

## § 830.200

(5) Verify or validate work before approval and implementation of the design.

(g) Criterion 7—Performance/Procurement.

(1) Procure items and services that meet established requirements and perform as specified.

(2) Evaluate and select prospective suppliers on the basis of specified criteria.

(3) Establish and implement processes to ensure that approved suppliers continue to provide acceptable items and services.

(h) Criterion 8—Performance/Inspection and Acceptance Testing.

(1) Inspect and test specified items, services, and processes using established acceptance and performance criteria.

(2) Calibrate and maintain equipment used for inspections and tests.

(i) Criterion 9—Assessment/Management Assessment. Ensure managers assess their management processes and identify and correct problems that hinder the organization from achieving its objectives.

(j) Criterion 10—Assessment/Independent Assessment.

(1) Plan and conduct independent assessments to measure item and service quality, to measure the adequacy of work performance, and to promote improvement.

(2) Establish sufficient authority, and freedom from line management, for the group performing independent assessments.

(3) Ensure persons who perform independent assessments are technically qualified and knowledgeable in the areas to be assessed.

### Subpart B—Safety Basis Requirements

#### § 830.200 Scope.

This Subpart establishes safety basis requirements for hazard category 1, 2, and 3 DOE nuclear facilities.

#### § 830.201 Performance of work.

A contractor must perform work in accordance with the safety basis for a hazard category 1, 2, or 3 DOE nuclear facility and, in particular, with the hazard controls that ensure adequate

## 10 CFR Ch. III (1–1–05 Edition)

protection of workers, the public, and the environment.

#### § 830.202 Safety basis.

(a) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must establish and maintain the safety basis for the facility.

(b) In establishing the safety basis for a hazard category 1, 2, or 3 DOE nuclear facility, the contractor responsible for the facility must:

(1) Define the scope of the work to be performed;

(2) Identify and analyze the hazards associated with the work;

(3) Categorize the facility consistent with DOE-STD-1027-92 (“Hazard Categorization and Accident Analysis Techniques for compliance with DOE Order 5480.23, Nuclear Safety Analysis Reports,” Change Notice 1, September 1997);

(4) Prepare a documented safety analysis for the facility; and (5) Establish the hazard controls upon which the contractor will rely to ensure adequate protection of workers, the public, and the environment.

(c) In maintaining the safety basis for a hazard category 1, 2, or 3 DOE nuclear facility, the contractor responsible for the facility must:

(1) Update the safety basis to keep it current and to reflect changes in the facility, the work and the hazards as they are analyzed in the documented safety analysis;

(2) Annually submit to DOE either the updated documented safety analysis for approval or a letter stating that there have been no changes in the documented safety analysis since the prior submission; and

(3) Incorporate in the safety basis any changes, conditions, or hazard controls directed by DOE.

#### § 830.203 Unreviewed safety question process.

(a) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must establish, implement, and take actions consistent with a USQ process that meets the requirements of this section.

(b) The contractor responsible for a hazard category 1, 2, or 3 DOE existing nuclear facility must submit for DOE