

§ 149.417

p.s.i./520 k.p.a. for a natural gas deepwater port)—measured at the two most remote nozzles.

(b) Each fire pump must have:

(1) A relief valve on its discharge side that is set to relieve at 25 p.s.i./173 k.p.a in excess of the pressure necessary to meet the requirement in paragraph (a) of this section;

(2) A pressure gauge on its discharge side; and

(3) Its own sea connection.

(c) Fire pumps may only be connected to the fire-main system.

(d) The fire pumps required by paragraph (a) of this section must be located in separate spaces and the arrangement of pumps, sea connections, controls, and sources of power must be such as to ensure that a fire, in any one space, will not put all of the fire pumps out of service.

(e) The fire pumps must be capable of being started and stopped from outside the spaces in which they are located.

§ 149.417 What are the requirements for fire hydrants?

(a) Fire hydrants must comply with 46 CFR 108.423.

(b) A single length of fire hose, with an attached nozzle, must be connected to each fire hydrant at all times. If the hose is exposed to freezing weather, it may be removed from the location during freezing weather.

(c) Each fire hydrant must have a shutoff valve.

(d) Any equipment that is located in the same space as the fire hydrant must not impede access to the hydrant.

(e) Each fire hydrant must have at least one spanner wrench at the fire hydrant.

§ 149.418 What are the requirements for fire hoses and fire nozzles?

(a) Fire hoses must comply with 46 CFR 108.425 and be:

(1) Prominently marked in accordance with 46 CFR 97.37-15; and

(2) If in an exposed location, protected from freezing weather.

(b) Each fire hose and nozzle must comply with 46 CFR 108.425 or a national consensus standard, as that term is defined in 29 CFR 1910.2, for such hose and nozzle and the standards set by a nationally recognized testing

33 CFR Ch. I (7-1-05 Edition)

laboratory, as that term is defined in 29 CFR 1910.7, for such hose.

§ 149.419 What are the requirements for a dry chemical fire-suppression system?

Each natural gas deepwater port must be equipped with a dry chemical system that meets the requirements of § 127.609 to this chapter.

§ 149.420 What firefighting equipment must a helicopter landing deck on a manned deepwater port have?

Each helicopter landing deck on a manned deepwater port must have the following:

(a) A fire hydrant and hose located near each stairway access to the landing deck. If the landing deck has more than two stairway accesses, only two stairway accesses need to have a fire hydrant and hose. The fire hydrants must be part of the fire-main system; and

(b) Portable fire extinguishers in the quantity and location as required in table 149.409.

§ 149.421 What fire-protection system must a helicopter fueling facility have?

In addition to the portable fire extinguishers required under table 149.409, each helicopter fueling facility must have a fire-protection system complying with 46 CFR 108.489.

§ 149.422 Can the water supply for the helicopter deck fire-protection system be part of a firewater system?

(a) The water supply for the helicopter deck fire-protection system required under §§ 149.420 or 149.421 may be part of:

(1) The firewater system (installed in accordance with MMS regulations under 30 CFR 250.803); or

(2) The fire-main system under § 149.415.

(b) If the water supply for the helicopter deck fire-protection system is part of an independent accommodation fire-main system, the piping design and hardware must be compatible with the system and must comply with the requirements for fire-mains in 46 CFR 108.415 through 108.429.