

§ 410.32

do not qualify under the water jet weaving subdivision.

(b) The term *water jet weaving* shall mean the internal subdivision of the low water use processing subcategory for facilities primarily engaged in manufacturing woven greige goods through the water jet weaving process.

§ 410.32 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BPT):

GENERAL PROCESSING

Pollutant or pollutant property	BPT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (pounds per 1,000 lb) of product	
BOD5	1.4	0.7
COD	2.8	1.4
TSS	1.4	0.7
ph	(¹)	(¹)

¹ Within the range 6.0 to 9.0 at all times.

WATER JET WEAVING

Pollutant or pollutant property	BPT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (pounds per 1,000 lb) of product	
BOD5	8.9	4.6
COD	21.3	13.7
TSS	5.5	2.5
ph	(¹)	(¹)

¹ Within the range 6.0 to 9.0 at all times.

§ 410.33 Effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point

40 CFR Ch. I (7-1-06 Edition)

source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT):

GENERAL PROCESSING

Pollutant or pollutant property	BAT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (pounds per 1,000 lb) of product	
COD	2.8	1.4

WATER JET WEAVING

Pollutant or pollutant property	BAT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (pounds per 1,000 lb) of product	
COD	21.3	13.7

§ 410.34 Pretreatment standards for existing sources (PSES).

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

§ 410.35 New source performance standards (NSPS).

Any new source subject to this subpart must achieve the following new source performance standards (NSPS):

GENERAL PROCESSING

Pollutant or pollutant property	NSPS	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (pounds per 1,000 lb) of product	
BOD5	1.4	0.7
COD	2.8	1.4
TSS	1.4	0.7
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0 at all times.