

§ 415.133

process wastewater equal to the difference between the mean precipitation for that month that falls within the impoundment and the mean evaporation for that month as established by the National Climatic Center, National Oceanic and Atmospheric Administration for the area in which such impoundment is located (or as otherwise determined if no monthly data have been established by the National Climatic Center).

(d) Any process wastewater discharged pursuant to paragraph (c) of this section shall comply with each of the following requirements:

SUBPART M—POTASSIUM SULFATE

Pollutant or pollutant property	BPT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Milligrams per liter (mg/l)	
TSS	50	25
ph	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

§ 415.133 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT):

(a) Subject to the provisions of paragraph (b) of this section there shall be no discharge of process wastewater pollutants into navigable waters.

(b) A process wastewater impoundment which is designed, constructed, and operated so as to contain the precipitation from the 25-year, 24-hour rainfall event as established by the National Climatic Center, National Oceanic and Atmospheric Administration for the area in which such impoundment is located may discharge that volume of process wastewater which is equivalent to the volume of precipitation that falls within the impoundment

in excess of that attributable to the 25-year, 24-hour rainfall event, when such event occurs.

§ 415.134 [Reserved]

§ 415.135 New source performance standards (NSPS).

Any new source subject to this subpart must achieve the following new source performance standards (NSPS):

(a) Subject to the provisions of paragraph (b) of this section there shall be no discharge of process wastewater pollutants into navigable waters.

(b) A process wastewater impoundment which is designed, constructed, and operated so as to contain the precipitation from the 25-year, 24-hour rainfall event as established by the National Climatic Center, National Oceanic and Atmospheric Administration for the area in which such impoundment is located may discharge that volume of process wastewater which is equivalent to the volume of precipitation that falls within the impoundment in excess of that attributable to the 25-year, 24-hour rainfall event, when such event occurs.

§ 415.136 Pretreatment standards for new sources (PSNS).

Except as provided in § 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources (PSNS): The limitations are the same as the new source performance standards specified in § 415.135.

Subpart N—Sodium Bicarbonate Production Subcategory

§ 415.140 Applicability; description of the sodium bicarbonate production subcategory.

The provisions of this subpart are applicable to discharges resulting from the production of sodium bicarbonate.