

**Environmental Protection Agency**

**§ 418.15**

(d) The concentration of pollutants discharged in contaminated non-process wastewater shall not exceed the values listed in the following table:

Effluent characteristic	Effluent limitations (mg/l)	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Total phosphorus (as P) .....	105	35
Fluoride .....	75	25

[39 FR 12836, Apr. 8, 1974, as amended at 41 FR 20584, May 19, 1976; 42 FR 16141, Mar. 25, 1977; 60 FR 33956, June 29, 1995]

**§ 418.13 Effluent limitations and guidelines representing the degree of effluent reduction attained by the application of the best available technology economically achievable.**

The following limitations establish the quantity or quality of pollutants or pollutant properties which may be discharged by a point source subject to the provisions of this subpart after application of the best available technology economically achievable:

(a) Subject to the provision of paragraphs (b) and (c) of this section, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best available technology economically achievable: There shall be no discharge of process wastewater pollutants to navigable waters.

(b) Process wastewater pollutants from a calcium sulfate storage pile runoff facility operated separately or in combination with a water recirculation system designed, constructed and operated to maintain a surge capacity equal to the runoff from the 25-year, 24-hour rainfall event may be discharged, after treatment to the standards set forth in paragraph (c) of this section, whenever chronic or catastrophic precipitation events cause the water level to rise into the surge capacity. Process wastewater must be treated and discharged whenever the water level equals or exceeds the midpoint of the surge capacity.

(c) The concentration of pollutants discharged in process wastewater pur-

suant to the limitations of paragraph (b) of this section shall not exceed the values listed in the following table:

Effluent characteristic	Effluent limitations (mg/l)	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Total phosphorus (as P) .....	105	35
Fluoride .....	75	25

(d) The concentration of pollutants discharged in contaminated non-process wastewater shall not exceed the values listed in the following table:

Effluent characteristic	Effluent limitations (mg/l)	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Total phosphorus (as P) .....	105	35
Fluoride .....	75	25

[39 FR 12836, Apr. 8, 1974, as amended at 41 FR 20584, May 19, 1976; 44 FR 50742, Aug. 29, 1979; 45 FR 37199, June 2, 1980]

**§ 418.14 [Reserved]**

**§ 418.15 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties which may be discharged by a new source subject to the provisions of this subpart:

(a) Subject to the provision of paragraphs (b) and (c) of this section, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best available demonstrated control technology: There shall be no discharge of process wastewater pollutants to navigable waters.

(b) Process wastewater pollutants from a calcium sulfate storage pile runoff facility operated separately or in combination with a water recirculation system designed, constructed and operated to maintain a surge capacity equal to the runoff from the 25-year, 24-hour rainfall event may be discharged, after treatment to the standards set