

Environmental Protection Agency

§ 419.42

Process configuration	Process factor
6.5 to 6.99	1.08
7.0 to 7.49	1.17
7.5 to 7.99	1.28
8.0 to 8.49	1.39
8.5 to 8.99	1.51
9.0 to 9.49	1.65
9.5 or greater	1.72

(3) See the comprehensive example in subpart D, § 419.42(b)(3).

(c) The provisions of § 419.16(c) apply to discharges of process wastewater pollutants attributable to ballast water by a point source subject to the provisions of this subpart.

(d) The quantity and quality of pollutants or pollutant properties controlled by this paragraph, attributable to once-through cooling water, are excluded from the discharge allowed by paragraph (b) of this section. Once-through cooling water may be discharged with a total organic carbon concentration not to exceed 5 mg/l.

(e) *Effluent Limitations for Runoff.* [Reserved]

[47 FR 46446, Oct. 18, 1982, as amended at 50 FR 28523, July 12, 1985; 50 FR 32414, Aug. 12, 1985]

§ 419.37 Pretreatment standards for new sources (PSNS).

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources (PSNS).

(a) The following standards apply to the total refinery flow contribution to the POTW:

Pollutant or pollutant property	Pretreatment standards for new sources maximum for any 1 day
	Milligrams per liter (mg/l)
Oil and grease	100
Ammonia (as N)	100

¹ Where the discharge to the POTW consists solely of sour waters, the owner or operator has the option of complying with this limit or the daily maximum mass limitation for ammonia set forth in § 419.36 (a) and (b).

(b) The following standard is applied to the cooling tower discharge part of the total refinery flow to the POTW by multiplying: (1) The standard; (2) by

the total refinery flow to the POTW; and (3) by the ratio of the cooling tower discharge flow to the total refinery flow.

Pollutant or pollutant property	Pretreatment standards for new sources maximum for any 1 day
	Milligrams per liter (mg/l)
Total chromium	1

Subpart D—Lube Subcategory

§ 419.40 Applicability; description of the lube subcategory.

The provisions of this subpart are applicable to all discharges from any facility that produces petroleum products by the use of topping, cracking, and lube oil manufacturing processes, whether or not the facility includes any process in addition to topping, cracking, and lube oil manufacturing processes. The provisions of this subpart are not applicable, however, to facilities that include the processes specified in subparts C and E of this part.

§ 419.41 Specialized definitions.

The general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter and the specialized definitions set forth in § 419.11 shall apply to this subpart.

§ 419.42 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

(a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):