

mixtures must use the PCB disposal requirements that apply to the individual phase with the highest PCB concentration except where otherwise noted. Alternatively, phases may be separated and disposed of using the PCB disposal requirements that apply to each separated, single-phase material.

(5) No person may avoid any provision specifying a PCB concentration by diluting the PCBs, unless otherwise specifically provided.

(6) Unless otherwise specified, references to weights or volumes of PCBs in this part apply to the total weight or total volume of the material (oil, soil, debris, etc.) that contains regulated concentrations of PCBs, not the calculated weight or volume of only the PCB molecules contained in the material.

(c) Definitions of the terms used in these regulations are in subpart A. The basic requirements applicable to disposal and marking of PCBs and PCB Items are set forth in subpart D—Disposal of PCBs and PCB Items and in subpart C—Marking of PCBs and PCB Items. Prohibitions applicable to PCB activities are set forth in subpart B—Manufacture, Processing, Distribution in Commerce, and Use of PCBs and PCB Items. Subpart B also includes authorizations from the prohibitions. Subparts C and D set forth the specific requirements for disposal and marking of PCBs and PCB Items.

(d) Section 15 of the Toxic Substances Control Act (TSCA) states that failure to comply with these regulations is unlawful. Section 16 imposes liability for civil penalties upon any person who violates these regulations, and the Administrator can establish appropriate remedies for any violations subject to any limitations included in section 16 of TSCA. Section 16 also subjects a person to criminal prosecution for a violation which is knowing or willful. In addition, section 17 authorizes Federal district courts to enjoin activities prohibited by these regulations, compel the taking of actions required by these regulations, and issue orders to seize PCBs and PCB Items manufactured, processed or distributed in violation of these regulations.

(e) These regulations do not preempt other more stringent Federal statutes and regulations.

(f) Unless and until superseded by any new more stringent regulations issued under EPA authorities, or any permits or any pretreatment requirements issued by EPA, a state or local government that affect release of PCBs to any particular medium:

(1) Persons who inadvertently manufacture or import PCBs generated as unintentional impurities in excluded manufacturing processes, as defined in § 761.3, are exempt from the requirements of subpart B of this part, provided that such persons comply with subpart J of this part, as applicable.

(2) Persons who process, distribute in commerce, or use products containing PCBs generated in excluded manufacturing processes defined in § 761.3 are exempt from the requirements of subpart B provided that such persons comply with subpart J of this part, as applicable.

(3) Persons who process, distribute in commerce, or use products containing recycled PCBs defined in § 761.3, are exempt from the requirements of subpart B of this part, provided that such persons comply with subpart J of this part, as applicable.

(4) Except as provided in § 761.20 (d) and (e), persons who process, distribute in commerce, or use products containing excluded PCB products as defined in § 761.3, are exempt from the requirements of subpart B of this part.

(Sec. 6, Pub. L. 94-469, 90 Stat. 2020 (15 U.S.C. 2605)

[44 FR 31542, May 31, 1979, as amended at 49 FR 28189, July 10, 1984; 53 FR 24220, June 27, 1988; 63 FR 35436, June 29, 1998; 64 FR 33759, June 24, 1999]

§ 761.2 PCB concentration assumptions for use.

(a)(1) Any person may assume that transformers with < 3 pounds (1.36 kilograms (kgs)) of fluid, circuit breakers, reclosers, oil-filled cable, and rectifiers whose PCB concentration is not established contain PCBs at < 50 ppm.

(2) Any person must assume that mineral oil-filled electrical equipment that was manufactured before July 2, 1979, and whose PCB concentration is not established is PCB-Contaminated

§761.3

40 CFR Ch. I (7-1-06 Edition)

Electrical Equipment (i.e., contains ≥ 50 ppm PCB, but < 500 ppm PCB). All pole-top and pad-mounted distribution transformers manufactured before July 2, 1979, must be assumed to be mineral-oil filled. Any person may assume that electrical equipment manufactured after July 2, 1979, is non-PCB (i.e., < 50 ppm PCBs). If the date of manufacture of mineral oil-filled electrical equipment is unknown, any person must assume it to be PCB-Contaminated.

(3) Any person must assume that a transformer manufactured prior to July 2, 1979, that contains 1.36 kg (3 pounds) or more of fluid other than mineral oil and whose PCB concentration is not established, is a PCB Transformer (i.e., ≥ 500 ppm). If the date of manufacture and the type of dielectric fluid are unknown, any person must assume the transformer to be a PCB Transformer.

(4) Any person must assume that a capacitor manufactured prior to July 2, 1979, whose PCB concentration is not established contains ≥ 500 ppm PCBs. Any person may assume that a capacitor manufactured after July 2, 1979, is non-PCB (i.e., < 50 ppm PCBs). If the date of manufacture is unknown, any person must assume the capacitor contains ≥ 500 ppm PCBs. Any person may assume that a capacitor marked at the time of manufacture with the statement "No PCBs" in accordance with §761.40(g) is non-PCB.

(b) PCB concentration may be established by:

(1) Testing the equipment; or

(2)(i) A permanent label, mark, or other documentation from the manufacturer of the equipment indicating its PCB concentration at the time of manufacture; and

(ii) Service records or other documentation indicating the PCB concentration of all fluids used in servicing the equipment since it was first manufactured.

[63 FR 35436, June 29, 1998, as amended at 64 FR 33759, June 24, 1999]

§761.3 Definitions.

For the purpose of this part:

Administrator means the Administrator of the Environmental Protection Agency, or any employee of the Agency to whom the Administrator may either

herein or by order delegate his authority to carry out his functions, or any person who shall by operation of law be authorized to carry out such functions.

Agency means the United States Environmental Protection Agency.

Air compressor system means air compressors, piping, receiver tanks, volume tanks and bottles, dryers, airlines, and related appurtenances.

Annual document log means the detailed information maintained at the facility on the PCB waste handling at the facility.

Annual report means the written document submitted each year by each disposer and commercial storer of PCB waste to the appropriate EPA Regional Administrator. The annual report is a brief summary of the information included in the annual document log.

ASTM means American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

Byproduct means a chemical substance produced without separate commercial intent during the manufacturing or processing of another chemical substance(s) or mixture(s).

Capacitor means a device for accumulating and holding a charge of electricity and consisting of conducting surfaces separated by a dielectric. Types of capacitors are as follows:

(1) *Small capacitor* means a capacitor which contains less than 1.36 kg (3 lbs.) of dielectric fluid. The following assumptions may be used if the actual weight of the dielectric fluid is unknown. A capacitor whose total volume is less than 1,639 cubic centimeters (100 cubic inches) may be considered to contain less than 1.36 kgs (3 lbs.) of dielectric fluid and a capacitor whose total volume is more than 3,278 cubic centimeters (200 cubic inches) must be considered to contain more than 1.36 kg (3 lbs.) of dielectric fluid. A capacitor whose volume is between 1,639 and 3,278 cubic centimeters may be considered to contain less than 1.36 kg (3 lbs.) of dielectric fluid if the total weight of the capacitor is less than 4.08 kg (9 lbs.).

(2) *Large high voltage capacitor* means a capacitor which contains 1.36 kg (3 lbs.) or more of dielectric fluid and which operates at 2,000 volts (a.c. or d.c.) or above.