

**§ 71.25-1**

(d) For inspection procedures of electrical engineering equipment and systems, see subchapter J (Electrical Engineering) of this chapter.

(e) For inspection and testing standards of structural subdivision integrity, see § 72.01-25 of this subchapter.

(f) For inspection and testing of watertight doors, see § 170.270 of this chapter.

[CGFR 65-50, 30 FR 16895, Dec. 30, 1965, as amended by CGD 79-023, 48 FR 51007, Nov. 4, 1983; CGD 84-069, 61 FR 25287, May 20, 1996]

**Subpart 71.25—Annual Inspection**

**§ 71.25-1 Prerequisite of reissuance of certificate of inspection.**

(a) The annual inspection is a prerequisite of the reissuance of a certificate of inspection.

(b) [Reserved]

**§ 71.25-5 When made.**

(a) The annual inspection will be made only upon the written application of the master, owner, or agent of the vessel on Form CG-3752, Application for Inspection of U.S. Vessel, to the Officer in Charge, Marine Inspection, at or nearest the port where the vessel is to be inspected.

(b) You must submit your application for the annual inspection at least 30 days before your current certificate of inspection expires.

[CGFR 65-50, 30 FR 16895, Dec. 30, 1965, as amended by USCG-1999-4976, 65 FR 6501, Feb. 9, 2000]

**§ 71.25-10 Scope of inspections.**

The annual inspection shall include an inspection of the structure, boilers, and other pressure vessels, machinery and equipment. The inspection shall be such as to insure that the vessel, as regards the structure, boilers and other pressure vessels, and their appurtenances, piping, main and auxiliary machinery, electrical installations, life-saving appliances, fire-detecting and extinguishing equipment, pilot boarding equipment, and other equipment is in satisfactory condition and fit for the service for which it is intended, and that it complies with the applicable regulations for such vessels, and determine that the vessel is in pos-

**46 CFR Ch. I (10-1-06 Edition)**

session of a valid certificate issued by the Federal Communications Commission, if required. The lights, means of making sound signals, and distress signals carried by the vessel shall also be subject to the above-mentioned inspection for the purpose of ensuring that they comply with the requirements of the applicable statutes and regulations.

[CGFR 68-32, 33 FR 5715, Apr. 12, 1968 as amended by CGD 82-036, 48 FR 655, Jan. 6, 1983; CGD 79-032, 49 FR 25455, June 21, 1984; CGD 95-012, 60 FR 48051, Sept. 18, 1995]

**§ 71.25-15 Lifesaving equipment.**

For inspection procedures of life-saving appliances and arrangements, see subchapter W (Lifesaving Appliances and Arrangements) of this chapter.

[CGD 84-069, 61 FR 25287, May 20, 1996]

**§ 71.25-20 Fire-detecting and extinguishing equipment.**

(a) At each annual inspection, the inspector shall conduct the following tests and inspections of fire detecting and extinguishing equipment:

(1) All hand portable fire extinguishers and semiportable fire extinguishing systems shall be checked as noted in table 71.25-20(a)(1). In addition, the hand portable fire extinguishers and semiportable fire extinguishing systems shall be examined for excessive corrosion and general condition.

TABLE 71.25-20(a)(1)

| Type unit  | Test  |
|--|---|
| Soda acid .....  | Discharge. Clean hose and inside of extinguisher thoroughly. Recharge.  |
| Foam .....   | Discharge. Clean hose and inside of extinguisher thoroughly. Recharge.  |
| Pump tank (water or antifreeze).                         | Discharge. Clean hose and inside of extinguisher thoroughly. Recharge with clean water or antifreeze.   |
| Cartridge operated (water, antifreeze or loaded stream). | Examine pressure cartridge and replace if end is punctured or if cartridge is otherwise determined to have leaked or to be in unsuitable condition. Remove liquid. Clean hose and inside of extinguisher thoroughly. Recharge with clean water, solution or antifreeze. Insert charged cartridge. |

TABLE 71.25-20(a)(1)—Continued

| Type unit                                   | Test  |
|---|---|
| Carbon Dioxide .....                        | Weigh cylinders. Recharge if weight loss exceed 10 percent of weight of charge. Inspect hose and nozzle to be sure they are clear. <sup>1</sup>   |
| Dry chemical (cartridge-operated type).     | Examine pressure cartridge and replace if end is punctured or if cartridge is otherwise determined to have leaked or to be in unsuitable condition. Inspect hose and nozzle to see they are clear. Insert charged cartridge. Be sure dry chemical is free-flowing (not caked) and chamber contains full charge. |
| Dry chemical (stored pressure type).        | See that pressure gage is in operating range. If not, or if seal is broken, weigh or otherwise determine that full charge of dry chemical is in extinguisher. Recharge if pressure is low or if dry chemical is needed.   |
| Vaporizing liquid <sup>2</sup> (pump type). | Pump a few strokes into clean pail and replace liquid. Keep water out of extinguisher or liquid. Keep extinguisher completely full of liquid.   |
| Vaporizing liquid (stored pressure type).   | See that pressure gage is in operating range. Weigh or check liquid level to determine that full charge of liquid is in extinguisher. Recharge if pressure is low or if liquid is needed.   |

<sup>1</sup> Cylinders must be tested and marked, and all flexible connections and discharge hoses of semi-portable carbon dioxide and halon extinguishers must be tested or renewed, as required by §§ 147.60 and 147.65 of this chapter.

<sup>2</sup> Vaporizing-liquid type fire extinguishers containing carbon tetrachloride or chlorobromomethane or other toxic vaporizing liquids shall be removed from all vessels. (See § 76.50-5(e) of this subchapter.)

(2) Fixed fire extinguishing systems shall be checked as noted in table 71.25-20(a)(2). In addition all parts of the fixed fire extinguishing systems shall be examined for excessive corrosion and general conditions.

TABLE 71.25-20(a)(2)

| Type system          | Test   |
|----------------------|--|
| Foam .....           | Systems utilizing a soda solution shall have such solution replaced. In all cases, ascertain that powder is not caked. |
| Carbon dioxide ..... | Weigh cylinders. Recharge if weight loss exceeds 10 percent of weight of charge. <sup>1</sup>                          |

<sup>1</sup> Cylinders must be tested and marked, and all flexible connections on fixed carbon dioxide systems must be tested or renewed, as required by §§ 147.60 and 147.65 of this chapter.

(3) All fire detecting and extinguishing systems, all piping controls, valves, and alarms shall be checked to ascertain that the system is in operating condition. In this respect, auto-

matic sprinkling systems shall be checked by means of test stations or opening heads, smoke detecting systems shall be checked by introducing smoke into the accumulators, fire detecting and manual alarm systems shall be checked by test stations or actuating detectors or pull boxes, and steam smothering lines shall be checked with at least a 50 p.s.i. air pressure with the ends capped or by blowing steam through the lines at the designed pressure.

(4) The fire main system shall be operated and the pressure checked at the most remote and highest outlets. All fire hose shall be subjected to the test pressure equivalent to the maximum pressure to which they may be subjected in service, but not less than 100 p.s.i.

(b) [Reserved]

[CGFR 65-50, 30 FR 16895, Dec. 30, 1965, as amended by CGFR 68-32, 33 FR 5716, Apr. 12, 1968; CGD 84-044, 53 FR 7748, Mar. 10, 1988]

**§ 71.25-25 Hull equipment.**

(a) At each annual inspection, the inspector shall conduct the following tests and inspections of hull equipment:

(1) All subdivision bulkheads shall be examined to determine that their watertight integrity has not been impaired.

(2) All watertight doors shall be operated locally by manual power and also by hydraulic or electric power if so fitted. Where remote control is fitted, the doors shall also be operated by the remote control apparatus.

(3) All magnetically controlled fire doors shall be operated locally and by the remote control, and all automatic fire dampers shall be checked to determine that they are in an operable condition.

(4) The remote controls of all valves shall be operated.

(5) The owner, operator or master shall provide the Officer in Charge, Marine Inspection with all current valid certificates and registers of cargo gear issued by an organization recognized by the Commandant under § 31.10-16.

(b) Every acceptable cargo gear certificate and/or register shall be properly executed by a person authorized to do so and shall: