

**Environmental Protection Agency**

**§ 432.125**

**PERFORMANCE STANDARDS  
[NSPS]**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
Ammonia (as N) .....	8.0	4.0
BOD <sub>5</sub> .....	26	16
Fecal Coliform .....	( <sup>2</sup> )	( <sup>3</sup> )
O&G (as HEM) .....	14	8.0
TSS .....	30	20

<sup>1</sup> mg/L (ppm).  
<sup>2</sup> Maximum of 400 MPN or CFU per 100 mL at any time.  
<sup>3</sup> No maximum monthly average limitation.

(b) Facilities that slaughter more than 100 million pounds per year (in units of LWK) must achieve the following performance standards:

**PERFORMANCE STANDARDS  
[NSPS]**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
Ammonia (as N) .....	8.0	4.0
BOD <sub>5</sub> .....	26	16
Fecal Coliform .....	( <sup>2</sup> )	( <sup>3</sup> )
O&G (as HEM) .....	14	8.0
TSS .....	30	20
Total Nitrogen .....	147	103

<sup>1</sup> mg/L (ppm).  
<sup>2</sup> Maximum of 400 MPN or CFU per 100 mL at any time.  
<sup>3</sup> No maximum monthly average limitation.

**§ 432.116 Pretreatment standards for new sources (PSNS). [Reserved]**

**§ 432.117 Effluent limitations attainable by the application of the best control technology for conventional pollutants (BCT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BCT: Limitations for BOD<sub>5</sub>, TSS, O&G (as HEM), and fecal coliform are the same as the corresponding limitation specified in § 432.112.

**Subpart L—Poultry Further Processing**

**§ 432.120 Applicability.**

This part applies to discharges of process wastewater resulting from further processing of poultry.

**§ 432.121 Special definitions. [Reserved]**

**§ 432.122 Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart that further processes more than 7 million pounds per year (in units of finished product) must achieve the following effluent limitations representing the application of BPT:

**EFFLUENT LIMITATIONS  
[BPT]**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
Ammonia (as N) .....	8.0	4.0
BOD <sub>5</sub> .....	26	16
Fecal Coliform .....	( <sup>2</sup> )	( <sup>3</sup> )
O&G (as HEM) .....	14	8.0
TSS .....	30	20

<sup>1</sup> mg/L (ppm).  
<sup>2</sup> Maximum of 400 MPN or CFU per 100 mL at any time.  
<sup>3</sup> No maximum monthly average limitation.

**§ 432.123 Effluent limitations attainable by the application of the best available technology economically achievable (BAT).**

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart that further processes more than 7 million pounds per year (in units of finished product) must achieve the following effluent limitations representing the application of BAT:

**EFFLUENT LIMITATIONS  
[BAT]**

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
Ammonia (as N) .....	8.0	4.0
Total Nitrogen .....	147	103

<sup>1</sup> mg/L (ppm).

**§ 432.124 Pretreatment standards for existing sources (PSES). [Reserved]**

**§ 432.125 New source performance standards (NSPS).**

Any source that is a new source subject to this subpart must achieve the following performance standards: