

§ 460.11

§ 460.11 Specialized definitions.

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

(b) The term “product” shall mean service resulting from the hospital activity in terms of 1,000 occupied beds.

§ 460.12 Effluent limitations and guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart, shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

(a) The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this paragraph, which may be discharged from the hospital point source subject to the provisions of this paragraph after application of the best practicable control technology currently available:

| Effluent characteristic | Effluent limitations                   |   |
|-------------------------|--|---|
|                         | Maximum for any 1 day                  | Average of daily values for 30 consecutive days shall not exceed— |
|                         | Metric units (kg/1,000 occupied beds)  |   |
| BOD <sub>5</sub> .....  | 41.0                                   | 33.6  |
| TSS .....               | 55.6                                   | 33.8  |
| pH .....                | ( <sup>1</sup> )                       | ( <sup>1</sup> )  |
|                         | English units (lb/1,000 occupied beds) |   |
| BOD <sub>5</sub> .....  | 90.4                                   | 74.0  |
| TSS .....               | 122.4                                  | 74.5  |
| pH .....                | ( <sup>1</sup> )                       | ( <sup>1</sup> )  |

<sup>1</sup> Within the range 6.0 to 9.0.

[41 FR 18777, May 6, 1976, as amended at 60 FR 33972, June 29, 1995]

PART 461—BATTERY MANUFACTURING POINT SOURCE CATEGORY

GENERAL PROVISIONS

Sec.

- 461.1 Applicability.
- 461.2 General definitions.
- 461.3 Monitoring and reporting requirements.
- 461.4 Compliance date for PSES.

Subpart A—Cadmium Subcategory

- 461.10 Applicability; description of the cadmium subcategory.
- 461.11 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).
- 461.12 Effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).
- 461.13 New source performance standards (NSPS).
- 461.14 Pretreatment standards for existing sources (PSES).
- 461.15 Pretreatment standards for new sources (PSNS).

Subpart B—Calcium Subcategory

- 461.20 Applicability; description of the calcium subcategory.
- 461.21–461.22 [Reserved]
- 461.23 New source performance standards (NSPS).
- 461.24 [Reserved]
- 461.25 Pretreatment standards for new sources (PSNS).

Subpart C—Lead Subcategory

- 461.30 Applicability; description of the lead subcategory.
- 461.31 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).
- 461.32 Effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).
- 461.33 New source performance standards (NSPS).
- 461.34 Pretreatment standards for existing sources (PSES).
- 461.35 Pretreatment standards for new sources (PSNS).