

(8) If you demonstrate compliance with an applicable mercury emission limit through performance testing, and you plan to burn a new type of fuel or a new mixture of fuels, you must recalculate the maximum mercury input using Equation 7 of § 63.7530. If the results of recalculating the maximum mercury input using Equation 7 of § 63.7530 are higher than the maximum mercury input level established during the previous performance test, then you must conduct a new performance test within 60 days of burning the new fuel type or fuel mixture according to the procedures in § 63.7520 to demonstrate that the mercury emissions do not exceed the emission limit. You must also establish new operating limits based on this performance test according to the procedures in § 63.7530(c).

(9) If your unit is controlled with a fabric filter, and you demonstrate continuous compliance using a bag leak detection system, you must initiate corrective action within 1 hour of a bag leak detection system alarm and complete corrective actions as soon as practical, and operate and maintain the fabric filter system such that the alarm does not sound more than 5 percent of the operating time during a 6-month period. You must also keep records of the date, time, and duration of each alarm, the time corrective action was initiated and completed, and a brief description of the cause of the alarm and the corrective action taken. You must also record the percent of the operating time during each 6-month period that the alarm sounds. In calculating this operating time percentage, if inspection of the fabric filter demonstrates that no corrective action is required, no alarm time is counted. If corrective action is required, each alarm shall be counted as a minimum of 1 hour. If you take longer than 1 hour to initiate corrective action, the alarm time shall be counted as the actual amount of time taken to initiate corrective action.

(10) If you have an applicable work practice standard for carbon monoxide, and you are required to install a CEMS according to § 63.7525(a), then you must meet the requirements in paragraphs (a)(10)(i) through (iii) of this section.

(i) You must continuously monitor carbon monoxide according to §§ 63.7525(a) and 63.7535.

(ii) Maintain a carbon monoxide emission level below your applicable carbon monoxide work practice standard in Table 1 to this subpart at all times except during periods of startup, shutdown, malfunction, and when your boiler or process heater is operating at less than 50 percent of rated capacity.

(iii) Keep records of carbon monoxide levels according to § 63.7555(b).

(b) You must report each instance in which you did not meet each emission limit, operating limit, and work practice standard in Tables 1 through 4 to this subpart that apply to you. You must also report each instance during a startup, shutdown, or malfunction when you did not meet each applicable emission limit, operating limit, and work practice standard. These instances are deviations from the emission limits and work practice standards in this subpart. These deviations must be reported according to the requirements in § 63.7550.

(c) [Reserved]

(d) Consistent with §§ 63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if you demonstrate to the EPA Administrator's satisfaction that you were operating in accordance with § 63.6(e)(1). The EPA Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in § 63.6(e).

[69 FR 55253, Sept. 13, 2004, as amended at 71 FR 20467, Apr. 20, 2006]

§ 63.7541 How do I demonstrate continuous compliance under the emission averaging provision?

(a) Following the compliance date, the owner or operator must demonstrate compliance with this subpart on a continuous basis by meeting the requirements of paragraphs (a)(1) through (4) of this section.

(1) For each calendar month, demonstrate compliance with the average

weighted emissions limit for the existing large solid fuel boilers participating in the emissions averaging option as determined in § 63.7522(f) and (g);

(2) For each existing solid fuel boiler participating in the emissions averaging option that is equipped with a dry control system, maintain opacity at or below the applicable limit;

(3) For each existing solid fuel boiler participating in the emissions averaging option that is equipped with a wet scrubber, maintain the 3-hour average parameter values at or below the operating limits established during the most recent performance test; and

(4) For each existing solid fuel boiler participating in the emissions averaging option that has an approved alternative operating plan, maintain the 3-hour average parameter values at or below the operating limits established in the most recent performance test.

(b) Any instance where the owner or operator fails to comply with the continuous monitoring requirements in paragraphs (a)(1) through (4) of this section, except during periods of startup, shutdown, and malfunction, is a deviation.

NOTIFICATION, REPORTS, AND RECORDS

§ 63.7545 What notifications must I submit and when?

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8 (e), (f)(4) and (6), and 63.9 (b) through (h) that apply to you by the dates specified.

(b) As specified in § 63.9(b)(2), if you startup your affected source before November 12, 2004, you must submit an Initial Notification not later than 120 days after November 12, 2004. The Initial Notification must include the information required in paragraphs (b)(1) and (2) of this section, as applicable.

(1) If your affected source has an annual capacity factor of greater than 10 percent, your Initial Notification must include the information required by § 63.9(b)(2).

(2) If your affected source has a federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent such that the unit is in one of the limited use subcat-

egories (the limited use solid fuel subcategory, the limited use liquid fuel subcategory, or the limited use gaseous fuel subcategory), your Initial Notification must include the information required by § 63.9(b)(2) and also a signed statement indicating your affected source has a federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent.

(c) As specified in § 63.9(b)(4) and (b)(5), if you startup your new or reconstructed affected source on or after November 12, 2004, you must submit an Initial Notification not later than 15 days after the actual date of startup of the affected source.

(d) If you are required to conduct a performance test you must submit a Notification of Intent to conduct a performance test at least 30 days before the performance test is scheduled to begin.

(e) If you are required to conduct an initial compliance demonstration as specified in § 63.7530(a), you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii). For each initial compliance demonstration, you must submit the Notification of Compliance Status, including all performance test results and fuel analyses, before the close of business on the 60th day following the completion of the performance test and/or other initial compliance demonstrations according to § 63.10(d)(2). The Notification of Compliance Status report must contain all the information specified in paragraphs (e)(1) through (9), as applicable.

(1) A description of the affected source(s) including identification of which subcategory the source is in, the capacity of the source, a description of the add-on controls used on the source description of the fuel(s) burned, and justification for the fuel(s) burned during the performance test.

(2) Summary of the results of all performance tests, fuel analyses, and calculations conducted to demonstrate initial compliance including all established operating limits.

(3) Identification of whether you are complying with the particulate matter emission limit or the alternative total selected metals emission limit.