

record the data required in appendix C to this part, pursuant to § 75.58(b).

(b) For an affected unit equipped with add-on SO<sub>2</sub> emission controls, the designated representative may petition the Administrator to approve a parametric monitoring procedure, as described in appendix C of this part, for calculating substitute SO<sub>2</sub> concentration data for missing data periods. The owner or operator shall use the procedures in §§ 75.31, 75.33, or 75.34(a) for providing substitute data for missing SO<sub>2</sub> concentration data unless a parametric monitoring procedure has been approved by the Administrator.

(1) Where the monitor data availability is 90.0 percent or more for an outlet SO<sub>2</sub> pollutant concentration monitor, the owner or operator may calculate substitute data using an approved parametric monitoring procedure.

(2) Where the monitor data availability for an outlet SO<sub>2</sub> pollutant concentration monitor is less than 90.0 percent, the owner or operator shall calculate substitute data using the procedures in § 75.34(a) (1) or (2), even if the Administrator has approved a parametric monitoring procedure.

(c) For an affected unit with NO<sub>x</sub> add-on emission controls, the designated representative may petition the Administrator to approve a parametric monitoring procedure, as described in appendix C of this part, in order to calculate substitute NO<sub>x</sub> emission rate data for missing data periods. The owner or operator shall use the procedures in § 75.31 or 75.33 for providing substitute data for missing NO<sub>x</sub> emission rate data prior to receiving the Administrator's approval for a parametric monitoring procedure.

(1) Where monitor data availability for a NO<sub>x</sub> continuous emission monitoring system is 90.0 percent or more, the owner or operator may calculate substitute data using an approved parametric monitoring procedure.

(2) Where monitor data availability for a NO<sub>x</sub> continuous emission monitoring system is less than 90.0 percent, the owner or operator shall calculate substitute data using the procedure in § 75.34(a) (1) or (2), even if the Administrator has approved a parametric monitoring procedure.

(d) In order to implement the options in paragraphs (a)(1) and (a)(3) of this section, the owner or operator shall keep records of information as described in § 75.58(b)(3) to verify the proper operation of all add-on SO<sub>2</sub> or NO<sub>x</sub> emission controls, during all periods of SO<sub>2</sub> or NO<sub>x</sub> emission missing data. If the owner or operator elects to implement the missing data option in paragraph (a)(2) of this section, the records in § 75.58(b)(3) are required to be kept only for the ozone season. The owner or operator shall document in the quality assurance/quality control (QA/QC) program required by section 1 of appendix B to this part, the parameters monitored and (as applicable) the ranges and combinations of parameters that indicate proper operation of the controls. The owner or operator shall provide the information recorded under § 75.58(b)(3) and the related QA/QC program information to the Administrator, to the EPA Regional Office, or to the appropriate State or local agency, upon request.

[60 FR 26567, May 17, 1995, as amended at 61 FR 59160, Nov. 20, 1996; 64 FR 28604, May 26, 1999; 67 FR 40438, June 12, 2002]

#### § 75.35 Missing data procedures for CO<sub>2</sub>.

(a) The owner or operator of a unit with a CO<sub>2</sub> continuous emission monitoring system for determining CO<sub>2</sub> mass emissions in accordance with § 75.10 (or an O<sub>2</sub> monitor that is used to determine CO<sub>2</sub> concentration in accordance with appendix F to this part) shall substitute for missing CO<sub>2</sub> pollutant concentration data using the procedures of paragraphs (b) and (d) of this section.

(b) During the first 720 quality-assured monitor operating hours following initial certification at a particular unit or stack location (i.e., the date and time at which quality-assured data begins to be recorded by a CEMS at that location), or (when implementing these procedures for a previously certified CO<sub>2</sub> monitoring system) during the 720 quality-assured monitor operating hours preceding implementation of the standard missing data procedures in paragraph (d) of this section, the owner or operator shall

### § 75.36

provide substitute CO<sub>2</sub> pollutant concentration data or substitute CO<sub>2</sub> data for heat input determination, as applicable, according to the procedures in § 75.31(b).

(c) [Reserved]

(d) Upon completion of 720 quality-assured monitor operating hours using the initial missing data procedures of § 75.31(b), the owner or operator shall provide substitute data for CO<sub>2</sub> concentration or substitute CO<sub>2</sub> data for heat input determination, as applicable, in accordance with the procedures in § 75.33(b) except that the term "CO<sub>2</sub> concentration" shall apply rather than "SO<sub>2</sub> concentration," the term "CO<sub>2</sub> pollutant concentration monitor" or "CO<sub>2</sub> diluent monitor" shall apply rather than "SO<sub>2</sub> pollutant concentration monitor," and the term "maximum potential CO<sub>2</sub> concentration, as defined in section 2.1.3.1 of appendix A to this part" shall apply, rather than "maximum potential SO<sub>2</sub> concentration."

[67 FR 40439, June 12, 2002]

#### § 75.36 Missing data procedures for heat input rate determinations.

(a) When hourly heat input rate is determined using a flow monitoring system and a diluent gas (O<sub>2</sub> or CO<sub>2</sub>) monitor, substitute data must be provided to calculate the heat input whenever quality-assured data are unavailable from the flow monitor, the diluent gas monitor, or both. When flow rate data are unavailable, substitute flow rate data for the heat input rate calculation shall be provided according to § 75.31 or § 75.33, as applicable. When diluent gas data are unavailable, the owner or operator shall provide substitute O<sub>2</sub> or CO<sub>2</sub> data for the heat input rate calculations in accordance with paragraphs (b) and (d) of this section.

(b) During the first 720 quality-assured monitor operating hours following initial certification at a particular unit or stack location (*i.e.*, the date and time at which quality-assured data begins to be recorded by a CEMS at that location), or (when implementing these procedures for a previously certified CO<sub>2</sub> or O<sub>2</sub> monitor) during the 720 quality-assured monitor operating hours preceding implementation of the standard missing data pro-

### 40 CFR Ch. I (7-1-07 Edition)

cedures in paragraph (d) of this section, the owner or operator shall provide substitute CO<sub>2</sub> or O<sub>2</sub> data, as applicable, for the calculation of heat input (under section 5.2 of appendix F to this part) according to § 75.31(b).

(c) [Reserved]

(d) Upon completion of 720 quality-assured monitor operating hours using the initial missing data procedures of § 75.31(b), the owner or operator shall provide substitute data for CO<sub>2</sub> or O<sub>2</sub> concentration to calculate heat input rate, as follows. Substitute CO<sub>2</sub> data for heat input rate determinations shall be provided according to § 75.35(d). Substitute O<sub>2</sub> data for the heat input rate determinations shall be provided in accordance with the procedures in § 75.33(b), except that the term "O<sub>2</sub> concentration" shall apply rather than the term "SO<sub>2</sub> concentration" and the term "O<sub>2</sub> diluent monitor" shall apply rather than the term "SO<sub>2</sub> pollutant concentration monitor." In addition, the term "substitute the lesser of" shall apply rather than "substitute the greater of;" the terms "minimum hourly O<sub>2</sub> concentration" and "minimum potential O<sub>2</sub> concentration, as determined under section 2.1.3.2 of appendix A to this part" shall apply rather than, respectively, the terms "maximum hourly SO<sub>2</sub> concentration" and "maximum potential SO<sub>2</sub> concentration, as determined under section 2.1.1.1 of appendix A to this part;" and the terms "10th percentile" and "5th percentile" shall apply rather than, respectively, the terms "90th percentile" and "95th percentile" (see Table 1 of § 75.33).

[60 FR 26530, May 17, 1995, as amended at 64 FR 28604, May 26, 1999; 67 FR 40439, June 12, 2002]

#### § 75.37 Missing data procedures for moisture.

(a) The owner or operator of a unit with a continuous moisture monitoring system shall substitute for missing moisture data using the procedures of this section.

(b) Where no prior quality-assured moisture data exist, substitute the minimum potential moisture percentage, from section 2.1.5 of appendix A to this part, except when Equation 19-3, 19-4 or 19-8 in Method 19 in appendix A