

the control period immediately before such allowance transfer deadline.

(c) Where a CAIR NO_x allowance transfer submitted for recordation fails to meet the requirements of paragraph (a) of this section, the Administrator will not record such transfer.

§97.162 Notification.

(a) *Notification of recordation.* Within 5 business days of recordation of a CAIR NO_x allowance transfer under §97.161, the Administrator will notify the CAIR authorized account representatives of both the transferor and transferee accounts.

(b) *Notification of non-recordation.* Within 10 business days of receipt of a CAIR NO_x allowance transfer that fails to meet the requirements of §97.161(a), the Administrator will notify the CAIR authorized account representatives of both accounts subject to the transfer of:

(1) A decision not to record the transfer, and

(2) The reasons for such non-recordation.

(c) Nothing in this section shall preclude the submission of a CAIR NO_x allowance transfer for recordation following notification of non-recordation.

Subpart HH—Monitoring and Reporting

§97.170 General requirements.

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NO_x unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this subpart and in subpart H of part 75 of this chapter. For purposes of complying with such requirements, the definitions in §97.102 and in §72.2 of this chapter shall apply, and the terms “affected unit,” “designated representative,” and “continuous emission monitoring system” or “CEMS”) in part 75 of this chapter shall be deemed to refer to the terms “CAIR NO_x unit,” “CAIR designated representative,” and “continuous emission monitoring system” (or “CEMS”) respectively, as defined in §97.102. The owner or operator of a unit that is not a CAIR NO_x unit but that is monitored under §75.72(b)(2)(ii) of this chapter

shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NO_x unit.

(a) *Requirements for installation, certification, and data accounting.* The owner or operator of each CAIR NO_x unit shall:

(1) Install all monitoring systems required under this subpart for monitoring NO_x mass emissions and individual unit heat input (including all systems required to monitor NO_x emission rate, NO_x concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with (§§75.71 and 75.72 of this chapter);

(2) Successfully complete all certification tests required under §97.171 and meet all other requirements of this subpart and part 75 of this chapter applicable to the monitoring systems under paragraph (a)(1) of this section; and

(3) Record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.

(b) *Compliance deadlines.* Except as provided in paragraph (e) of this section, the owner or operator shall meet the monitoring system certification and other requirements of paragraphs (a)(1) and (2) of this section on or before the following dates. The owner or operator shall record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section on and after the following dates.

(1) For the owner or operator of a CAIR NO_x unit that commences commercial operation before July 1, 2007, by January 1, 2008.

(2) For the owner or operator of a CAIR NO_x unit that commences commercial operation on or after July 1, 2007, by the later of the following dates:

(i) January 1, 2008; or

(ii) 90 unit operating days or 180 calendar days, whichever occurs first, after the date on which the unit commences commercial operation.

(3) For the owner or operator of a CAIR NO_x unit for which construction of a new stack or flue or installation of add-on NO_x emission controls is completed after the applicable deadline under paragraph (b)(1), (2), (4), or (5) of