

852.209-70 Organizational conflicts of interest.

The following provision will be used as prescribed in 809.508-2:

ORGANIZATIONAL CONFLICTS OF INTEREST
(APR 1984)

(a) The offeror represents to the best of his/her knowledge and belief that the award of the contract would not involve organizational conflicts of interest as defined in this representation. The term organizational conflicts of interests shall mean that a relationship exists whereby an offeror or a contractor (including his/her chief executive, directors, proposed consultants and subcontractors) has interests which may: (1) Diminish his/her capacity to give impartial, technically sound, objective assistance and advice or may otherwise result in a biased work product; or (2) result in an unfair competitive advantage. It does not include the "normal flow of benefits" from the performance of a contract.

(b) Based on this representation and any other information solicited by the contracting officer, it may be determined organizational conflicts of interest exist which would warrant disqualifying the contractor for award of the contract unless the organizational conflicts of interest can be mitigated to the contracting officer's satisfaction by negotiating terms and conditions of the contract to that effect. In the case of a formally advertised solicitation, the apparent successful offeror may enter into a supplemental agreement which mitigates the organizational conflicts of interest.

(c) Nondisclosure or misrepresentations of organizational conflicts of interest at the time of the offer, or arising as a result of a modification to the contract, may result in the termination of the contract at no expense to the Government.

(End of provision)

[49 FR 12629, Mar. 29, 1984, as amended at 50 FR 794, Jan. 7, 1985]

852.211-70 Requirements for operating and maintenance manuals.

(a) Solicitations and requests for proposals for technical medical and other technical equipment and devices issued by a field facility will normally require the contractor to provide operating and maintenance manuals.

(b) The purpose of the requirement is for the manufacturer to provide the Department of Veterans Affairs a manual or groups of manuals that will allow the in-house repair of the equip-

ment purchased. Unless the facility Chief, Engineering Service, indicates that such service manuals are not needed, each invitation for bid or request for proposal for technical medical or other technical equipment and devices will include the following clauses for operating and maintenance manuals:

SERVICE DATA MANUAL (NOV 1984)

(a) The successful bidder will supply operation/service (maintenance) manuals with each piece of equipment in the quantity specified in the solicitation and resulting purchase order. As a minimum, the manual(s) shall be bound and equivalent to the manual(s) provided the manufacturer's designated field service representative as well as comply with all the requirements in paragraphs (b) through (i) of this clause. Sections, headings and section sequence identified in (b) through (i) of this clause are typical and may vary between manufacturers. Variances in the sections, headings and section sequence, however, do not relieve the manufacturer of his responsibility in supplying the technical data called for therein.

(b) *Title Page and Front Matter*—The title page shall include the equipment nomenclature, model number, effective date of the manual and the manufacturer's name and address. If the manual applies to a particular version of the equipment only, the title page shall also list that equipment's serial number. Front matter shall consist of the Table of Contents, List of Tables, List of Illustrations and a frontispiece (photograph or line drawing) depicting the equipment.

(c) *Section I, General Description*—This section shall provide a generalized description of the equipment or devices and shall describe its purpose or intended use. Included in this section will be a table listing all pertinent equipment specifications, power requirements, environmental limitations and physical dimensions.

(d) *Section II, Installation*—Section II shall provide pertinent installation information. It shall list all input and output connectors using applicable reference designators and functional names as they appear on the equipment. Included in this listing will be a brief description of the function of each connector along with the connector type. Instructions shall be provided as to the recommended method of repacking the equipment for shipment (packing material, labeling, etc.).

(e) *Section III, Operation*—Section III will fully describe the operation of the equipment and shall include a listing of each control with a brief description of its function and step-by-step procedures for each operating