

**§ 654.411**

Laundry rooms, toilets, privies, hallways, stairways, etc., shall contain adequate ceiling or wall-type light fixtures. At least one wall-type electrical convenience outlet shall be provided in each individual living room.

(c) Adequate lighting shall be provided for the yard area, and pathways to common use facilities.

(d) All wiring and lighting fixtures shall be installed and maintained in a safe condition.

**§ 654.411 Toilets.**

(a) Toilets shall be constructed, located and maintained so as to prevent any nuisance or public health hazard.

(b) Water closets or privy seats for each sex shall be in the ratio of not less than one such unit for each 15 occupants, with a minimum of one unit for each sex in common use facilities.

(c) Urinals, constructed of non-absorbent materials, may be substituted for men's toilet seats on the basis of one urinal or 24 inches of trough-type urinal for one toilet seat up to a maximum of one-third of the required toilet seats.

(d) Except in individual family units, separate toilet accommodations for men and women shall be provided. If toilet facilities for men and women are in the same building, they shall be separated by a solid wall from floor to roof or ceiling. Toilets shall be distinctly marked "men" and "women" in English and in the native language of the persons expected to occupy the housing.

(e) Where common use toilet facilities are provided, an adequate and accessible supply of toilet tissue, with holders, shall be furnished.

(f) Common use toilets and privies shall be well lighted and ventilated and shall be clean and sanitary.

(g) Toilet facilities shall be located within 200 feet of each living unit.

(h) Privies shall not be located closer than 50 feet from any living unit or any facility where food is prepared or served.

(i) Privy structures and pits shall be fly tight. Privy pits shall have adequate capacity for the required seats.

**20 CFR Ch. V (4-1-08 Edition)**

**§ 654.412 Bathing, laundry, and handwashing.**

(a) Bathing and handwashing facilities, supplied with hot and cold water under pressure, shall be provided for the use of all occupants. These facilities shall be clean and sanitary and located within 200 feet of each living unit.

(b) There shall be a minimum of 1 showerhead per 15 persons. Showerheads shall be spaced at least 3 feet apart, with a minimum of 9 square feet of floor space per unit. Adequate, dry dressing space shall be provided in common use facilities. Shower floors shall be constructed of nonabsorbent nonskid materials and sloped to properly constructed floor drains. Except in individual family units, separate shower facilities shall be provided each sex. When common use shower facilities for both sexes are in the same building they shall be separated by a solid non-absorbent wall extending from the floor to ceiling, or roof, and shall be plainly designated "men" or "women" in English and in the native language of the persons expected to occupy the housing.

(c) Lavatories or equivalent units shall be provided in a ratio of 1 per 15 persons.

(d) Laundry facilities, supplied with hot and cold water under pressure, shall be provided for the use of all occupants. Laundry trays or tubs shall be provided in the ratio of 1 per 25 persons. Mechanical washers may be provided in the ratio of 1 per 50 persons in lieu of laundry trays, although a minimum of 1 laundry tray per 100 persons shall be provided in addition to the mechanical washers.

**§ 654.413 Cooking and eating facilities.**

(a) When workers or their families are permitted or required to cook in their individual unit, a space shall be provided and equipped for cooking and eating. Such space shall be provided with:

(1) A cookstove or hot plate with a minimum of two burners; and (2) adequate food storage shelves and a counter for food preparation; and (3) provisions for mechanical refrigeration of food at a temperature of not more than 45° F.; and (4) a table and chairs or