

GENERAL

§ 1228.220 What authority applies to this subpart?

NARA is authorized to establish, maintain and operate records centers for Federal agencies under 44 U.S.C. 2907. NARA is authorized, under 44 U.S.C. 3103, to approve a records center that is maintained and operated by an agency. NARA is also authorized to promulgate standards, procedures, and guidelines to Federal agencies with respect to the storage of their records in commercial records storage facilities. See 44 U.S.C. 2104(a), 2904 and 3102. The regulations in this subpart apply to all records storage facilities Federal agencies use to store, service, and dispose of their records.

§ 1228.222 What does this subpart cover?

(a) This subpart covers the establishment, maintenance, and operation of records centers, whether Federally-owned and operated by NARA or another Federal agency, or Federally-owned and contractor operated. This subpart also covers an agency's use of commercial records storage facilities. Records centers and commercial records storage facilities are referred to collectively as records storage facilities. This subpart specifies the minimum structural, environmental, property, and life-safety standards that a records storage facility must meet when the facility is used for the storage of Federal records.

(b) Except where specifically noted, this subpart applies to all records storage facilities. Certain noted provisions apply only to new records storage facilities established or placed in service on or after September 28, 2005.

[64 FR 67642, Dec. 2, 1999, as amended at 70 FR 50986, Aug. 29, 2005]

§ 1228.224 Publications incorporated by reference.

(a) *General.* The following publications cited in this section are hereby incorporated by reference into this subpart K of part 1228. They are available from the issuing organizations at the addresses listed in this section. They are also available for inspection at the National Archives and Records Admin-

istration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. This incorporation by reference was approved by the Director of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR Part 51. These materials are incorporated as they exist on the date of approval, and a document indicating any change in these materials will be published in the FEDERAL REGISTER.

(b) *American Society of Testing and Materials (ASTM) standards.* The following ASTM standard is available from the American Society of Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA, 19428-2959, or on-line at www.astm.org:

E 119-98, Standard Test Methods for Fire Tests of Building Construction and Materials.

(c) *National Fire Protection Association (NFPA) standards.* The following NFPA standards are available from the National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9109, Quincy, MA 02269-9101, or on-line at <http://catalog.nfpa.org>:

NFPA 10, Standard for Portable Fire Extinguishers (1994 Edition).

NFPA 13, Standard for Installation of Sprinkler Systems (2002 Edition), IBR approved for §§ 1228.228(a)(1), 1228.230(e), and 1228.230(i).

NFPA 20, Standard for the Installation of Centrifugal Fire Pumps (1996 Edition).

NFPA 40, Standard for the Storage and Handling of Cellulose Nitrate Motion Picture Film (1997 Edition).

NFPA 42, Code for the Storage of Pyroxylin Plastic (1997 Edition).

NFPA 54, National Fuel Gas Code (2002 Edition), IBR approved for § 1228.230.

NFPA 72, National Fire Alarm Code (1996 Edition).

NFPA 101, Life Safety Code (1997 Edition).

NFPA 221, Standard for Fire Walls and Fire Barrier Walls (1994 Edition).

NFPA 231, Standard for General Storage (1998 Edition).

NFPA 231C, Standard for Rack Storage of Materials (1998 Edition).

NFPA 232, Standard for the Protection of Records (1995 Edition).

NFPA 232A, Guide for Fire Protection of Archives and Records Centers (1995 Edition).

(d) *Underwriters Laboratory (UL) standards.* The following UL standards

are available from the Underwriters Laboratory at *www.ul.com* or from Global Engineering Documents, 15 Inverness Way East, Englewood, CO 80112:

UL 611, Central-Station Burglar-Alarm Systems (February 22, 1996).

UL 827, Central-Station Alarm Services (April 23, 1999).

UL 1076, Proprietary Burglar Alarm Units and Systems (February 1, 1999).

(e) *American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) standards.* The following ASHRAE standards are available from ASHRAE at ASHRAE Customer Service, 1791 Tullie Circle NE, Atlanta, GA 30329 or online at *www.ASHRAE.org*:

ANSI/ASHRAE 55-1992, Thermal Environmental Conditions for Human Occupancy.

ANSI/ASHRAE 62-1989, Ventilation for Acceptable Indoor Air Quality.

(f) *American National Standards Institute (ANSI) standards.* The following ANSI standards are available from the American National Standards Institute, 11 West 42nd St., New York, NY 10036:

ANSI/NAPM IT9.18-1996, Imaging Materials—Processed Photographic Plates—Storage Practices.

ANSI/NAPM IT9.20-1996, Imaging Materials—Reflection Prints—Storage Practices.

ANSI/NAPM IT9.23-1996, Imaging Materials—Polyester Base Magnetic Tape—Storage.

ANSI/PIMA IT9.11-1998, Imaging Materials—Processed Safety Photographic Films—Storage.

ANSI/PIMA IT9.25-1998, Imaging Materials—Optical Disc Media—Storage.

(g) *International Association of Plumbing and Mechanical Officials (IAPMO) standards.* The following IAPMO standard is available from the International Association of Plumbing and Mechanical Officials, 5001 E. Philadelphia Street, Ontario, CA 91761: IAPMO, Uniform Mechanical Code (2003 Edition), IBR approved for § 1228.230.

[64 FR 67642, Dec. 2, 1999, as amended at 67 FR 79518, Dec. 30, 2002; 70 FR 50986, Aug. 29, 2005]

§ 1228.226 Definitions.

The following definitions apply to this subpart:

Auxiliary spaces mean non-records storage areas such as offices, research rooms, other work and general storage areas but excluding boiler rooms or

rooms containing equipment operating with a fuel supply such as generator rooms.

Commercial records storage facility has the meaning specified in § 1220.14 of this chapter.

Existing records storage facility means any records center or commercial records storage facility used to store records on September 27, 2005, and that has stored records continuously since that date.

Fire barrier wall means a wall, other than a fire wall, having a fire resistance rating, constructed in accordance with NFPA 221 (1994), Standard for Fire Walls and Fire Barrier Walls, Chapter 4.

Licensed fire protection engineer means a licensed or registered professional engineer with a recognized specialization in fire protection engineering. For those States that do not separately license or register fire protection engineers, a licensed or registered professional engineer with training and experience in fire protection engineering, operating within the scope of that licensing or registration, who is also a professional member of the Society of Fire Protection Engineers.

Must and *provide* mean that a provision is mandatory.

New records storage facility means any records center or commercial records storage facility established or converted for use as a records center or commercial records storage facility on or after September 28, 2005.

Permanent record has the meaning specified in § 1220.14 of this chapter.

Records center has the meaning specified in § 1220.14 of this chapter.

Records storage area means the area intended for long-term storage of records that is enclosed by four fire barrier walls, the floor, and the ceiling.

Records storage facility has the meaning specified in § 1220.14 of this chapter.

Sample/select records means records whose final disposition requires an analytical or statistical sampling prior to final disposition authorization, in which some percentage of the original accession will be retained as permanent records.

Should or *may* means that a provision is recommended or advised but not required.