

the in-line kiln/raw mill, or the alkali bypass in excess of $41\mu\text{g/dscm}$ if the source is a new or reconstructed source that commenced construction after December 2, 2005. As an alternative to meeting the $41\mu\text{g/dscm}$ standard you may route the emissions through a packed bed or spray tower wet scrubber with a liquid-to-gas (l/g) ratio of 30 gallons per 1000 actual cubic feet per minute (acfm) or more and meet a site-specific emissions limit based on the measured performance of the wet scrubber.

(d) *Existing kilns located at area sources.* No owner or operator of an existing kiln or an existing in-line kiln/raw mill located at a facility that is an area source subject to the provisions of this subpart shall cause to be discharged into the atmosphere from these affected sources any gases which:

(1) Contain D/F in excess of 0.20 ng per dscm (8.7×10^{-11} gr per dscf) (TEQ); or

(2) Contain D/F in excess of 0.40 ng per dscm (1.7×10^{-10} gr per dscf) (TEQ) when the average of the performance test run average temperatures at the inlet to the particulate matter control device is $204\text{ }^{\circ}\text{C}$ ($400\text{ }^{\circ}\text{F}$) or less.

(e) *New or reconstructed kilns located at area sources.* No owner or operator of a new or reconstructed kiln or new or reconstructed in-line kiln/raw mill located at a facility that is an area source subject to the provisions of this subpart shall cause to be discharged into the atmosphere from these affected sources any gases which:

(1) Contain D/F in excess of:

(i) 0.20 ng per dscm (8.7×10^{-11} gr per dscf) (TEQ); or

(ii) 0.40 ng per dscm (1.7×10^{-10} gr per dscf) (TEQ) when the average of the performance test run average temperatures at the inlet to the particulate matter control device is $204\text{ }^{\circ}\text{C}$ ($400\text{ }^{\circ}\text{F}$) or less.

(2) Contain total hydrocarbons (THC), from the main exhaust of the kiln, or main exhaust of the in-line kiln/raw mill, in excess of 20 ppmv if the source is a new or reconstructed source that commenced construction after December 2, 2005. As an alternative to meeting the 20 ppmv standard you may demonstrate a 98 percent reduction of THC emissions from the exit

of the kiln to discharge to the atmosphere. If the source is a greenfield kiln that commenced construction on or prior to December 2, 2005, then the THC limit is 50 ppmv.

(3) Contain mercury from the main exhaust of the kiln, or main exhaust of the in-line kiln/raw mill, or the alkali bypass in excess of $41\mu\text{g/dscm}$ if the source is a new or reconstructed source that commenced construction after December 2, 2005. As an alternative to meeting the $41\mu\text{g/dscm}$ standard you may route the emissions through a packed bed or spray tower wet scrubber with a liquid-to-gas (l/g) ratio of 30 gallons per 1000 actual cubic feet per minute (acfm) or more and meet a site-specific emissions limit based on the measured performance of the wet scrubber.

[71 FR 76549, Dec. 20, 2006]

§ 63.1344 Operating limits for kilns and in-line kiln/raw mills.

(a) The owner or operator of a kiln subject to a D/F emission limitation under § 63.1343 must operate the kiln such that the temperature of the gas at the inlet to the kiln particulate matter control device (PMCD) and alkali bypass PMCD, if applicable, does not exceed the applicable temperature limit specified in paragraph (b) of this section. The owner or operator of an in-line kiln/raw mill subject to a D/F emission limitation under § 63.1343 must operate the in-line kiln/raw mill, such that:

(1) When the raw mill of the in-line kiln/raw mill is operating, the applicable temperature limit for the main in-line kiln/raw mill exhaust, specified in paragraph (b) of this section and established during the performance test when the raw mill was operating is not exceeded.

(2) When the raw mill of the in-line kiln/raw mill is not operating, the applicable temperature limit for the main in-line kiln/raw mill exhaust, specified in paragraph (b) of this section and established during the performance test when the raw mill was not operating, is not exceeded.

(3) If the in-line kiln/raw mill is equipped with an alkali bypass, the applicable temperature limit for the alkali bypass specified in paragraph (b)

of this section and established during the performance test, with or without the raw mill operating, is not exceeded.

(b) The temperature limit for affected sources meeting the limits of paragraph (a) of this section or paragraphs (a)(1) through (a)(3) of this section is determined in accordance with § 63.1349(b)(3)(iv).

(c) The owner or operator of an affected source subject to a mercury, THC or D/F emission limitation under § 63.1343 that employs carbon injection as an emission control technique must operate the carbon injection system in accordance with paragraphs (c)(1) and (c)(2) of this section.

(1) The three-hour rolling average activated carbon injection rate shall be equal to or greater than the activated carbon injection rate determined in accordance with § 63.1349(b)(3)(vi).

(2) The owner or operator shall either:

(i) Maintain the minimum activated carbon injection carrier gas flow rate, as a three-hour rolling average, based on the manufacturer's specifications. These specifications must be documented in the test plan developed in accordance with § 63.7(c), or

(ii) Maintain the minimum activated carbon injection carrier gas pressure drop, as a three-hour rolling average, based on the manufacturer's specifications. These specifications must be documented in the test plan developed in accordance with § 63.7(c).

(d) Except as provided in paragraph (e) of this section, the owner or operator of an affected source subject to a mercury, THC or D/F emission limitation under § 63.1343 that employs carbon injection as an emission control technique must specify and use the brand and type of activated carbon used during the performance test until a subsequent performance test is conducted, unless the site-specific performance test plan contains documentation of key parameters that affect adsorption and the owner or operator establishes limits based on those parameters, and the limits on these parameters are maintained.

(e) The owner or operator of an affected source subject to a D/F, THC, or mercury emission limitation under § 63.1343 that employs carbon injection

as an emission control technique may substitute, at any time, a different brand or type of activated carbon provided that the replacement has equivalent or improved properties compared to the activated carbon specified in the site-specific performance test plan and used in the performance test. The owner or operator must maintain documentation that the substitute activated carbon will provide the same or better level of control as the original activated carbon.

(f) Existing kilns and in-line kilns/raw mills must implement good combustion practices (GCP) designed to minimize THC from fuel combustion. GCP include training all operators and supervisors to operate and maintain the kiln and calciner, and the pollution control systems in accordance with good engineering practices. The training shall include methods for minimizing excess emissions.

(g) No kiln and in-line kiln/raw mill may use as a raw material or fuel any fly ash where the mercury content of the fly ash has been increased through the use of activated carbon, or any other sorbent unless the facility can demonstrate that the use of that fly ash will not result in an increase in mercury emissions over baseline emissions (i.e. emissions not using the fly ash). The facility has the burden of proving there has been no emissions increase over baseline.

(h) All kilns and in-line kilns/raw mills must remove (i.e. not recycle to the kiln) from the kiln system sufficient cement kiln dust to maintain the desired product quality.

(i) New and reconstructed kilns and in-line kilns/raw mills must not exceed the average hourly CKD recycle rate measured during mercury performance testing. Any exceedance of this average hourly rate is considered a violation of the standard.

[64 FR 31925, June 14, 1999, as amended at 67 FR 72585, Dec. 6, 2002; 71 FR 76550, Dec. 20, 2006]

§ 63.1345 Standards for clinker coolers.

(a) No owner or operator of a new or existing clinker cooler at a facility which is a major source subject to the provisions of this subpart shall cause to be discharged into the atmosphere