# § 192.125

(b) Plastic pipe may not be used where operating temperatures of the pipe will be:

(1) Below  $-20^{\circ}$ F  $(-20^{\circ}$ C), or  $-40^{\circ}$ F  $(-40^{\circ}$ C) if all pipe and pipeline components whose operating temperature will be below  $-29^{\circ}$ C  $(-20^{\circ}$ F) have a temperature rating by the manufacturer consistent with that operating temperature; or

(2) Above the following applicable temperatures:

(i) For thermoplastic pipe, the temperature at which the HDB used in the design formula under §192.121 is determined.

(ii) For reinforced thermosetting plastic pipe, 150°F (66°C).

(c) The wall thickness for thermoplastic pipe may not be less than 0.062 inches (1.57 millimeters).

(d) The wall thickness for reinforced thermosetting plastic pipe may not be less than that listed in the following table:

Nominal size in inches (millimeters).	Minimum wall thick- ness inches (millime- ters).
2 (51) 3 (76) 4 (102)	0.060 (1.52) 0.060 (1.52) 0.070 (1.78) 0.100 (2.54)

(e) The design pressure for thermoplastic pipe produced after July 14, 2004 may exceed a gauge pressure of 100 psig (689 kPa) provided that:

(1) The design pressure does not exceed 125 psig (862 kPa);

(2) The material is a PE2406 or a PE3408 as specified within ASTM D2513 (incorporated by reference, *see* § 192.7);

(3) The pipe size is nominal pipe size (IPS) 12 or less; and

(4) The design pressure is determined in accordance with the design equation defined in §192.121.

[35 FR 13257, Aug. 19, 1970, as amended by Amdt. 192–31, 43 FR 13883, Apr. 3, 1978; Amdt.
192–78, 61 FR 28783, June 6, 1996; Amdt. 192–85, 63 FR 37502, July 13, 1998; Amdt. 192–93, 68 FR 53900, Sept. 15, 2003; 69 FR 32894, June 14, 2004; Amdt. 192–94, 69 FR 54592, Sept. 9, 2004; Amdt.
192–103, 71 FR 33407, June 9, 2006]

### §192.125 Design of copper pipe.

(a) Copper pipe used in mains must have a minimum wall thickness of 0.065

# 49 CFR Ch. I (10–1–08 Edition)

inches (1.65 millimeters) and must be hard drawn.

(b) Copper pipe used in service lines must have wall thickness not less than that indicated in the following table:

Standard size inch	size inch O.D. inch	Wall thickness inch (milli- meter)	
(millimeter)		Nominal	Tolerance
1/2 (13) 5/8 (16) 3/4 (19) 1 (25) 11/4 (32) 11/2 (38)	.625 (16) .750 (19) .875 (22) 1.125 (29) 1.375 (35) 1.625 (41)	.040 (1.06) .042 (1.07) .045 (1.14) .050 (1.27) .055 (1.40) .060 (1.52)	.0035 (.0889) .0035 (.0889) .004 (.102) .004 (.102) .0045 (.1143) .0045 (.1143)

(c) Copper pipe used in mains and service lines may not be used at pressures in excess of 100 p.s.i. (689 kPa) gage.

(d) Copper pipe that does not have an internal corrosion resistant lining may not be used to carry gas that has an average hydrogen sulfide content of more than 0.3 grains/100 ft<sup>3</sup> ( $6.9/m^3$ ) under standard conditions. Standard conditions refers to  $60^{\circ}$ F and 14.7 psia ( $15.6^{\circ}$ C and one atmosphere) of gas.

[35 FR 13257, Aug. 19, 1970, as amended by Amdt. 192–62, 54 FR 5628, Feb. 6, 1989; Amdt. 192–85, 63 FR 37502, July 13, 1998]

### Subpart D—Design of Pipeline Components

## §192.141 Scope.

This subpart prescribes minimum requirements for the design and installation of pipeline components and facilities. In addition, it prescribes requirements relating to protection against accidental overpressuring.

### §192.143 General requirements.

(a) Each component of a pipeline must be able to withstand operating pressures and other anticipated loadings without impairment of its serviceability with unit stresses equivalent to those allowed for comparable material in pipe in the same location and kind of service. However, if design based upon unit stresses is impractical for a particular component, design may be based upon a pressure rating established by the manufacturer by pressure testing that component or a prototype of the component.

(b) The design and installation of pipeline components and facilities